2026, Jericho Design Group, LLC. These drawings are protected by the copyright laws of the United States. These drawings or any part thereof may not be used for any purpose or reproduced in any form or by any means without the written consent of Doug Shaw.

A. Prepare surfaces using methods recommended by manufacturer for achieving best result for substrate under the project conditions.
B. Coordinate with window installation and placement of concealed blocking to support shades.

3.03 INSTALLATION

A. Install in accordance with manufacturer's instructions and approved shop drawings, using mounting devices as indicated.
B. Replace shades that exceed specified dimensional tolerances at no extra cost to Owner.
C. Adjust level, projection, and shade centering from mounting bracket. Verify there is no telescoping of shade fabric. Ensure smooth shade operation.

3.04 SYSTEM STARTUP

A. Motorized Shade System: Provide services of a manufacturer's authorized representative to perform system startup.

3.05 CLEANING

A. Clean soiled shades and exposed components as recommended by manufacturer.
B. Replace shades that cannot be cleaned to "like new" condition.

3.06 PROTECTION

A. Protect installed products from subsequent construction operations.
B. Touch-up, repair, or replace damaged products before Substantial Completion.

END OF SECTION

SECTION 123100
MANUFACTURED METAL CASEWORK

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Manufactured standard and custom casework, with cabinet hardware.

1.02 REFERENCE STANDARDS

A. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2024.
B. BHMA A156.9 - Cabinet Hardware; 2020.

1.03 SUBMITTALS

A. Shop Drawings: Indicate casework types, sizes, locations, using large scale plans, elevations, cross sections. Include rough-in and anchors, placement dimensions and tolerances, clearances required, and keying information.
B. Samples: Two samples of each glazing material type. Minimum sample size: 2 by 3 inches (51 by 75 mm).
C. Manufacturer's qualification statement.
D. Installer's qualification statement.
E. Maintenance Data: Manufacturer's recommendations for care and cleaning.

1.04 DELIVERY, STORAGE, AND HANDLING

A. Protect items provided by this section during handling and installation, including finished surfaces and hardware items. For metal surfaces, use polyethylene film or other protective material standard with the manufacturer.
B. Accept casework on site. Inspect on arrival for damage.

1.05 WARRANTY

A. Manufacturer Warranty: Provide 5-year warranty against defects. Complete forms in Owner's name and register with manufacturer. Covered defects include, but are not limited to:
   1. Ruptured, cracked, or stained finish coating.
   2. Discoloration or lack of finish integrity.
   3. Cracking or peeling of finish.
   4. Failure of hardware.

PART 2 PRODUCTS

2.01 FABRICATION

A. Assembly: Shop assemble casework items for delivery to site in units easily handled and to permit passage through building openings.
B. Casework: Die-formed metal sheet; each unit self-contained and not dependent on adjacent units or building structure for rigidity; factory-fabricated, factory-assembled, and factory-finished.
   1. Style: Flush overlay - square edge.
   2. Primary Cabinet Material: Cold-rolled steel and Stainless steel.
   3. Cabinet Nominal Dimensions: Unless otherwise indicated, provide cabinets of widths and heights indicated on drawings, and with the following front-to-back dimensions:
      a. Base Cabinets: 24 inches (610 mm).
      b. Wall Cabinets: 16 inches (406 mm).
   4. Steel Sheet Metal:
      a. Gables, Front and Back Panels, Gusset Plates, Aprons, and Rails: 18 gauge, 0.0478 inch (1.21 mm) minimum thickness.
      b. Drawers, Cabinet Floors, Shelves, Filler Panels and Drawer Dividers: 20 gauge, 0.0359 inch (0.91 mm) minimum thickness.
      c. Backing Sheet to Door and Door Fronts: 22 gauge, 0.0299 inch (0.76 mm) minimum thickness.
   5. Structural Performance: Provide components that safely support the following minimum loads, without deformation or damage:
      a. Base Units: 500 pounds per linear foot (744 kg/linear m) across the cabinet ends.
   6. Seismic Performance: Casework, including attachments to other work, able to withstand the effects of earthquake motions determined according to ASCE/SEI 7.
      a. Component Importance Factor: 1.0.
   7. Corners and Joints: Without gaps or inaccessible spaces or areas where dirt or moisture could accumulate.
   8. Edges and Seams: Smooth. Form counter tops, shelves, and drain boards from continuous sheets.
   9. Shelf Edges: Turned down 3/4 inch (19 mm) on each side and returned 3/4 inch (19 mm) front and back.
   10. Ends: Close open ends with matching construction.
   11. Welding: Electric spot welded; joints ground smooth and flush.
   12. Drawers and Doors: Fabricate drawer and door fronts of sandwiched sheets of sheet steel welded together and reinforced for hardware.
      a. Fill with sound-deadening core.
   13. Fittings and Fixture Locations: Cut and drill countertops, backs, and other casework components for service outlets and fixtures.
   14. Access Panels: Where indicated, for maintenance of utility service fixtures and fittings and mechanical and electrical components.
   15. Fixed panels at backs of open spaces between base cabinets and at ends of utility spaces not otherwise enclosed.
   16. Filler Panels: Flanged on both sides, of matching construction and finish, for locations where cabinets do not fit tight to adjacent construction.
   17. Separation: Use bituminous paint or non-conductive tape to coat metal surfaces in contact with cementitious materials, and to separate dissimilar metals.

2.02 CABINET HARDWARE

A. Comply with BHMA A156.9 requirements.
B. Shelves in Cabinets:
   1. Shelf Standards and Rests: Vertical standards with rubber button fitted rests, satin chromium plated over nickel on base material.
C. Swinging Doors: Hinges, pulls, and catches.
   1. Hinges: Visible, number as required by referenced standards for width, height, and weight of door.
      a. Visible Hinges: Installed on framed cabinet face, and on door face, bright chromium plated over nickel on base material.
   2. Pulls: Chrome wire pulls, 4 inches (102 mm) wide.
   3. Catches: Magnetic.
D. Drawers: Pulls and slides.
   1. Pulls: Chrome wire pulls, 4 inches (102 mm) wide.
   2. Slides: Steel, full extension arms, ball bearings; self-closing; capacity as recommended by manufacturer for drawer height and width.

2.03 MATERIALS

A. General: Manufacturer's standard materials for units specified, unless otherwise indicated.
B. Stainless Steel Sheet: ASTM A666/A666M Type 304.

2.04 FINISHES

A. Coated Stainless Steel: Degrease and phosphate etch followed by primer; minimum two coats electrostatic enamel; red color as selected.
B. Stainless Steel: No. 4 finish.
C. Shop finish all components.

PART 3 EXECUTION

3.01 INSTALLATION

A. Install casework, components and accessories in accordance with manufacturer's instructions.
B. Use anchoring devices to suit conditions and substrate materials encountered.
C. Set casework items plumb and square, securely anchored to building structure, with no distortion.
   1. Base Cabinets: Examine floor levelness and flatness of installation space. Do not proceed with installation if encountered floor conditions require more than 3/4 inch (19 mm) leveling adjustment. When installation conditions are acceptable, for each space, establish the high point of the floor. Set and make level and plumb first cabinet in relation to this high point.
D. Align cabinets to adjoining components.
E. Fasten together cabinets in continuous runs, with joints flush, uniform and tight. Misalignment of adjacent units not to exceed 1/16 inch (1.6 mm). In addition, do not exceed the following tolerances:
   1. Variation of tops of Base Cabinets from Level: 1/16 inch (1.6 mm) in 10 feet (3 m).
   2. Variation of Bottoms of Upper Cabinets from Level: 1/8 inch (3 mm) in 10 feet (3 m) .
   3. Variation of Faces of Cabinets from a True Plane: 1/8 inch (3 mm) in 10 feet (3 m).
   4. Variation of Adjacent Surfaces from a True Plane (Lippage): 1/32 inch (0.8 mm).
   5. Variation in Alignment of Adjacent Door and Drawer Edges: 1/16 inch (1.6 mm).
F. Secure upper and floor cabinets to concealed reinforcement at gypsum board assemblies.
G. Separate dissimilar metals to prevent galvanic action.

END OF SECTION

SECTION 123600
COUNTERTOPS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Countertops for manufactured casework.
B. Wall-hung counters and vanity tops.

1.02 REFERENCE STANDARDS

A. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2024.
B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2024.
C. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards, 2nd Edition; 2014, with Errata (2016).
D. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards; 2021, with Errata.
E. ISFA 2-01 - Classification and Standards for Solid Surfacing Material; 2013.
F. NEMA LD 3 - High-Pressure Decorative Laminates; 2005.

1.03 SUBMITTALS

A. Product Data: Manufacturer's data sheets on each product to be used, including:
   1. Preparation instructions and recommendations.
   2. Storage and handling requirements and recommendations.
   3. Specimen warranty.
B. Shop Drawings: Complete details of materials and installation; combine with shop drawings of cabinets and casework specified in other sections.
C. Verification Samples: For each finish product specified, minimum size 6 inches (150 mm) square, representing actual product, color, and patterns.
D. Test Reports: Chemical resistance testing, showing compliance with specified requirements.
E. Installer's qualification statement.
F. Installation Instructions: Manufacturer's installation instructions and recommendations.
G. Maintenance Data: Manufacturer's instructions and recommendations for maintenance and repair of countertop surfaces.

1.04 QUALITY ASSURANCE

A. Fabricator Qualifications: Natural Stone Institute (NSI) Accredited Natural Stone Fabricator; www.naturalstoneinstitute.org/#sle.
B. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience and approved by manufacturer.

1.05 DELIVERY, STORAGE, AND HANDLING

A. Store products in manufacturer's unopened packaging until ready for installation.
B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.06 FIELD CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

PART 2 PRODUCTS

2.01 COUNTERTOPS

A. Quality Standard: Custom Grade, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
B. Solid Surfacing Countertops: Solid surfacing sheet or plastic resin casting over continuous substrate.
   1. Flat Sheet Thickness: 1/2 inch (12 mm), minimum.
   2. Solid Surfacing Sheet and Plastic Resin Castings: Complying with ISFA 2-01 and NEMA LD 3; acrylic or polyester resin, mineral filler, and pigments; homogenous, non-porous and capable of being worked and repaired using standard woodworking tools; no surface coating; color and pattern consistent throughout thickness.
      a. Manufacturers:
         1) Avonite Surfaces: www.avonitesurfaces.com/#sle.
         2) Dupont: www.corian.com/#sle.
         3) LG Hausys America, Inc: www.lghausysusa.com/#sle.
         4) Wilsonart: www.wilsonart.com/#sle.
      b. Surface Burning Characteristics: Flame spread index of 25, maximum; smoke developed index of 450, maximum; when tested in accordance with ASTM E84.
      c. Finish on Exposed Surfaces: Matte, gloss rating of 5 to 20.
      d. Color and Pattern: As indicated on drawings.
   3. Other Components Thickness: 1/2 inch (12 mm), minimum.
   4. Exposed Edge Treatment: Built up to minimum 1-1/4 inch (32 mm) thick; radiused edge.
   5. Back and End Splashes: Same sheet material, square top; minimum 4 inches (102 mm) high.
   6. Fabricate in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), Section 11 - Countertops, Premium Grade.
C. Stainless Steel Countertops: , Type 304, stainless steel sheet; 16 gauge, 0.0625 inch (1.59 mm) nominal sheet thickness.
   1. Finish: 4B satin brushed finish.
   2. Edge and Backsplash Sink Details: As indicated on drawings.
   3. Exposed Edge Shape: Straight turndown with return; 1-1/2 inch (38 mm) high face, 1/2 inch (12 mm) return to face of case ; reinforced with hardwood or steel.
   4. Back and End Splashes: Same material; welded 1/4 inch (6 mm) radius coved joint to countertop; square top edge with 1 inch (25 mm) wide top surface and minimum 1/2 inch (12 mm) turndown.
   5. Splash Dimensions: 4 inch (100 mm) high by 1 inch (25 mm) thick, unless otherwise indicated.
   6. Sinks: Same material, same thickness; flush welded to counter; bottom sloped to outlet; radiused interior corners; drain outlet located in back corner.

2.02 MATERIALS

A. Adhesives: Chemical resistant waterproof adhesive as recommended by manufacturer of materials being joined.
B. Joint Sealant: Mildew-resistant silicone sealant, clear.

2.03 ACCESSORIES

A. Fixed Top-Mounted Countertop Support Brackets:
   1. Material: Steel.
   2. Finish: Manufacturer's standard, factory-applied, textured powder coat.
   3. Color: To be selected by Architect.
   4. Products:
      a. Centerline Brackets; Front Mounting Countertop Support: www.countertopbracket.com/#sle.

2.04 FABRICATION

A. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.
   1. Join lengths of tops using best method recommended by manufacturer.
   2. Fabricate to overhang fronts and ends of cabinets 1 inch (25 mm) except where top butts against cabinet or wall.
   3. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.
B. Provide back/end splash wherever counter edge abuts vertical surface unless otherwise indicated.
   1. Secure to countertop with concealed fasteners and with contact surfaces set in waterproof glue.
   2. Height: 4 inches (102 mm), unless otherwise indicated.
C. Stainless Steel: Fabricate tops up to 144 inches (3,657 mm) long in one piece including nosings and back and end splashes; accurately fitted mechanical field joints in lengths over that dimension are permitted.
   1. Weld joints; grind smooth and polish to match.
   2. Provide stainless steel hat channel stiffeners, welded or soldered to underside, where indicated on drawings.
   3. Provide wall clips for support of back/end splash turndowns.
   4. Sound Deadening: Apply water resistant, fire resistant sound deadening mastic to entire bottom surface.

PART 3 EXECUTION

3.01 EXAMINATION

A. Do not begin installation until substrates have been properly prepared.
B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
C. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.

3.02 PREPARATION

A. Clean surfaces thoroughly prior to installation.
B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.03 INSTALLATION

A. Install vanities in accordance with manufacturer's instructions and approved shop drawings
B. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.
C. Attach stainless steel countertops using stainless steel fasteners and clips.
D. Seal joint between back/end splashes and vertical surfaces.

3.04 CLEANING

A. Clean countertops surfaces thoroughly.

3.05 PROTECTION

A. Protect installed products until completion of project.
B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

END OF SECTION

DIVISION 31 - EARTHWORK

SECTION 313116
TERMITE CONTROL

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Chemical soil treatment.

1.02 REFERENCE STANDARDS

A. Title 7, United States Code, 136 through 136y - Federal Insecticide, Fungicide and Rodenticide Act; 2022.

1.03 SUBMITTALS

A. Product Data: Indicate toxicants to be used, composition by percentage, dilution schedule, intended application rate.
B. Test Reports: Indicate regulatory agency approval reports when required.
C. Certificate of compliance from authority having jurisdiction indicating approval of toxicants.
D. Manufacturer's Instructions: Indicate caution requirement.
E. Record and document moisture content of soil before application, date and rate of application, areas of application, and diary of toxicity meter readings and corresponding soil coverage.
F. Installer Qualifications: Company specializing in performing work of the type specified and with minimum three (3) years of documented experience and approved by manufacturer.
G. Maintenance Data: Indicate re-treatment schedule .
H. Warranty: Submit warranty and ensure that forms have been completed in Owner's name.

1.04 WARRANTY

A. Provide five year installer's warranty against damage to building caused by termites.
   1. Include coverage for repairs to building and to contents damaged due to building damage. Repair damage and, if required, re-treat.
   2. Inspect annually and report in writing to Owner. Provide inspection service for minimum two years from Date of Substantial Completion.

PART 2 PRODUCTS

2.01 CHEMICAL SOIL TREATMENT

A. Toxicant Chemical: EPA Title 7, United States Code, 136 through 136y approved; synthetically color dyed to permit visual identification of treated soil.
B. Diluent: Recommended by toxicant manufacturer.
C. Manufacturers:
   1. Bayer Environmental Science Corporation: www.backedbybayer.com/pest-management/#sle.
   2. FMC Professional Solutions: www.fmcprosolutions.com/#sle.
   3. Syngenta Professional Products: www.syngentaprofessionalproducts.com/#sle.
D. Mixes: Mix toxicant to manufacturer's instructions.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify final grading is complete.

3.02 APPLICATION - CHEMICAL TREATMENT

A. Comply with requirements of U.S. EPA and applicable state and local codes.
B. Spray apply toxicant in accordance with manufacturer's instructions.
C. Apply toxicant at following locations:
   1. At Exterior Side of Foundation Surface.
D. At foundation walls, apply toxicant immediately prior to finish grading work outside foundations.
E. Apply extra treatment to structure penetration surfaces such as pipe or ducts, and soil penetrations such as grounding rods or posts.
F. Re-treat disturbed treated soil with same toxicant as original treatment.
G. If inspection or testing identifies the presence of termites, re-treat soil and re-test.

3.03 INSTALLATION - SITE-APPLIED TERMITICIDE

A. Comply with manufacturer's written instructions.

3.04 PROTECTION

A. Do not permit soil grading over treated work.
B. Protect sheet materials from damage after completed installation. Repair damage with manufacturer's recommended products and according to the manufacturer's written instructions.

END OF SECTION

JERICHO design group
208 Pirkle Ferry Road, Suite C
Cumming, GA 30040

STATE OF GEORGIA
DOUGLAS E SHAW
07/22/2026
CERTIFICATE NO. RA014575
REGISTERED ARCHITECT

georgia civil
CIVIL ENGINEERING
LANDSCAPE ARCHITECTURE
LAND SURVEYING

SHEAR STRUCTURAL

TOTAL ENGINEERS

Electrical Engineers

CITY OF COVINGTON
ESTABLISHED 1822
INCORPORATED 2005
FIRE RESCUE
GEORGIA
FIRE DEPARTMENT

FIRE STATION #23

City of Covington

HIGHWAY 36
COVINGTON, GA 30014

PRINT RECORD

No.	DATE	DESCRIPTION
	07/22/2026	ISSUED FOR PERMIT

Drawn By PG
Checked By JDG
Date 07/22/2026
Job No. 25033

Sheet Title
SPECIFICATIONS

Sheet No.
G-3.25

RELEASED FOR CONSTRUCTION