



GENERAL NOTES

A. WHERE MANUAL VOLUME DAMPERS ARE INACCESSIBLE DUE TO HARD CEILINGS, PROVIDE A YOUNG REGULATOR MODEL 270-895-LO CONCEALED CEILING REGULATOR WITH A 7/8-INCH THREADED CEILING CAP. PROVIDE BOWDEN CABLE/WIRE AS REQUIRED. INSTALL REGULATORS IN ACCORDANCE WITH THE MANUFACTURER'S WRITTEN INSTRUCTIONS. TYPICAL FOR ALL DAMPERS LOCATED ABOVE HARD CEILINGS SHOWN ON THE ARCHITECTURAL REFLECTED CEILING PLAN.



HIGHWAY 36
COVINGTON, GA 30014

Drawn By JSW	Checked By KP
Date 07/22/2026	Job No. 25-109

RELEASED FOR CONSTRUCTION