






- 1 ▶ PROVIDE JUNCTION BOX AT 42" A.F.F. WITH 1/2" CONDUIT TO GO UP IN WALL. ABOVE CEILING, AND STUBBED DOWN THROUGH CEILING AT LOCATION OF TELEPHONE BACKBOARD. PROVIDE 911 CALL BUTTON AND SPEAKER. COORDINATE EXACT LOCATION WITH OWNER/ARCHITECT TO ROUGH-IN.
- 2 ▶ PROVIDE JUNCTION BOX ON EXTERIOR WALL AT 42" A.F.F. FOR AIRPHONE PUSH BUTTON AND SPEAKER. PROVIDE (1) 1" IN. C. TO JUNCTION BOX AT 42" A.F.F. IN OFFICE FOR DESK MOUNTED AIRPHONE. COORDINATE EXACT LOCATION WITH OWNER/ARCHITECT TO ROUGH-IN.
- 3 ▶ PROVIDE A LOW FREQUENCY SOUNDER BASE FOR ALL SMOKE DETECTORS LOCATED IN BEDROOMS. (TYPICAL)



FIRE STATION #23

City of Covington

HIGHWAY 36
COVINGTON, GA 30014

PRINT RECORD

[illegible]

Drawn By TAW **Checked By** JHM

Date	Job No.
07/17/2026	25033

Sheet Title
**LEVEL 2 - LOW VOLTAGE
SYSTEMS**

Sheet No.

E-402

RELEASED FOR CONSTRUCTION