

ABBREVIATION		DESCRIPTION		MEP ABBREVIATIONS		ABBREVIATION		DESCRIPTION		ABBREVIATION		DESCRIPTION	
A	AMPERE	DHWP	DOMESTIC HOT WATER BOOSTER PUMP	FV	FULL VOLTAGE	MBH	BTUHR X 1000	SA	SUPPLY AIR / SOUND ATTENUATOR				
A/E	ARCHITECT AND ENGINEER	DHWST	DOMESTIC HOT WATER STORAGE TANK	FVNR	FULL VOLTAGE NON REVERSING	MC	MECHANICAL CONTRACTOR	SB	STEAM BOILER				
AAP	AREA ALARM PANEL	DI	DEIONIZED WATER	FWG	FOOD WASTE GRINDER	MCA	MINIMUM CIRCUIT AMPACITY	SC	STEAM COIL / SHORT CIRCUIT				
AC	AIR COMPRESSOR / ALTERNATING CURRENT	DIA	DIAMETER	G	GAS (NATURAL)	MCB	MAIN CIRCUIT BREAKER	SCC	STEAM CONDENSATE COOLER				
ACCU	AIR COOLED CONDENSING UNIT	DIR	DEIONIZED WATER RETURN	GA	GAUGE	MCC	MOTOR CONTROL CENTER	SCCH	SUBCOOLED CHILLER				
ACD	AIR CONDITIONING CONDENSATE DRAIN	DIS	DEIONIZED WATER SUPPLY	GAL	GALLON	MD	MOTORIZED DAMPER	SCCR	SHORT CIRCUIT CURRENT RATING				
ACP	ACCESS PANEL / AIR COMPRESSOR PUMP	DISC	DISCONNECT	GALV	GALVANIZED	MDF	MAIN DISTRIBUTION PANEL	SCFM	STANDARD CUBIC FEET PER MINUTE				
ACU	AIR CONDITIONING UNIT	DISCH	DISCHARGE	GB	GAS SUPPLY BOX	MECH	MECHANICAL	SCH	SCHEDULE				
AD	ACCESS DOOR / AREA DRAIN	DISS	DIAMETER INDEX SAFETY SYSTEM	GC	GENERAL CONTRACTOR	MFR	MANUFACTURER	SCW	SOFT COLD WATER (DOMESTIC)				
ADD	ADDITION	DIST	DISTANCE / DISTRIBUTION	GEN	GENERATOR	MH	MANHOLE	SD	SUPPLY DIFFUSER / SMOKE DAMPER				
ADJ	ADJUSTABLE / ADJACENT	DIXT	DI EXCHANGE TANKS	GFCI	GROUND FAULT CIRCUIT INTERRUPTER	MIN	MINIMUM	SEC	SECTION				
AFC	ABOVE FINISHED CEILING	DM	DEMAND METER	GFI	GROUND FAULT INTERRUPTER	MISC	MISCELLANEOUS	SENS	SENSIBLE				
AFDI	ARC FAULT CIRCUIT INTERRUPTER	DO	DRAWOUT	GFP	GROUND FAULT PROTECTION	MLO	MAIN LUGS ONLY	SEP	SEWAGE EJECTOR PUMP				
AFDV	AIRFLOW CONTROL VALVE	DOCS	DOCTORS	GH	GRAVITY HOOD	MOCP	MAXIMUM OVERCURRENT PROTECTION	SEER	SEASONAL ENERGY EFFICIENCY RATIO				
AF	AMPERE FRAME	DS	DOWNSPOUT / DISCONNECT SWITCH	GI	GREASE INTERCEPTOR	MPSR	MEDIUM PRESSURE CONDENSATE RETURN	SF	SUPPLY AIR FAN				
AFF	ABOVE FINISHED FLOOR	DST	DECONTAMINATION WATER STORAGE TANK	GND OR G	GROUND	MPS	MEDIUM PRESSURE STEAM	SG	SUPPLY GRILLE / SPECIAL GAS				
AFMS	AIR FLOW MEASURING STATION	DSWBP	DOMESTIC SOFT WATER BOOSTER PUMP	GRH	GALLONS PER HOUR	MTD	MOUNTED	SGP	SURGE GUARD PROTECTION				
AFG	ABOVE FINISHED GRADE	DT	DAY TANK	GPM	GALLONS PER MINUTE	MTG HT	MOUNTING HEIGHT	SH	SHOWER				
AHU	AIR HANDLING UNIT	DUC	DOOR UNDER CUT	GV	GAS VENT (NATURAL)	MJ	MEDICINE UNIT	SHT	SHEET				
AI	AIR INTAKE	DWG	DRAWING	GW	GREASE WATER	MV	MEDICAL VACUUM	SIG	SIGNAL				
AIC	AMPERE INTERRUPTING CAPACITY	DW	DISTILLED WATER / DISHWASHER	H	HUMIDITY / HUMIDITY / HEIGHT	MVO	MEDICAL VACUUM PUMP	SK	SINK				
AL	ALUMINUM	DWBP	DOMESTIC WATER BOOSTER PUMP	H2	HYDROGEN	MVO	MEDICAL VACUUM PUMP	SMH	SENSIBLE MBH				
AM	AMMETER	DWH	DOMESTIC WATER HEATER	HB	HOSE BIB	N2	NITROGEN	SMC	SHEET METAL CONTRACTOR				
AMB	AMBIENT	EA	EXHAUST AIR / EACH	HC	HEATING COIL	NM	NITROGEN MANIFOLD	SN	SOLID NEUTRAL				
AMP	AMPERE	EAT	ENTERING AIR TEMPERATURE	HCP	HEATING COIL PUMP (HOT WATER)	N2O	NITROUS OXIDE	SP	STATIC PRESSURE / SUMP PUMP				
APD	AIR PRESSURE DROP	EBH	ELECTRIC BASEBOARD HEATER	HD	HEAD	N2OM	NITROUS OXIDE MANIFOLD	SPEC	SPECIFICATIONS				
APPROX	APPROXIMATE	EC	ELECTRICAL CONTRACTOR	HE	HELIUM	NA OR N/A	NOT APPLICABLE	SQ	SQUARE				
AR	AIR RECEIVER	ECC	ENVIRONMENTAL CONTROL CONTRACTOR	HEM	HELIUM MANIFOLD	NC	NORMALLY CLOSED / NOISE CRITERIA	SQFT	SQUARE FEET				
ARC	ARC FLASH	ECO	EARTH CLEANOUT	HG	MERCURY	NIC	NOT IN CONTRACT	SRV	SAFETY RELIEF VALVE				
ARCH	ARCHITECT	EGG	EGG GRATE GRILLE	HGT	HEIGHT	NO	NORMALLY OPEN	SS	SOLID STATE SOFT START				
AS	AIR SEPARATOR	ED	EXHAUST DIFFUSER	HH	HANDHOLE	NSWC	NO SALT WATER CONTAINER	ST	STORM / STEAM TRAP				
AST	ABOVE-GROUND STORAGE TANK	EDC	ELECTRIC DUCT COIL	HD	HIGH INTENSITY DISCHARGE	NTS	NOT TO SCALE	STD	STANDARD				
ATM	ATMOSPHERE	EER	ENERGY EFFICIENCY RATIO	HO	HAND OPERATED	O2	OXYGEN	STN	STATION				
ATS	AUTOMATIC TRANSFER SWITCH	EEW	EMERGENCY EYE WASH	HOA	HAND-OFF-AUTOMATIC	O2M	OXYGEN MANIFOLD	STR	STARTER				
AUTO	AUTOMATIC	EF	EXHAUST FAN	HORZ	HORIZONTAL	OA	OUTSIDE AIR	STRUCT	STRUCTURAL				
AV	ACID VENT / AUDIO VISUAL	EFT	ENTERING FLUID TEMPERATURE	HOSP	HOSPITAL	OAT	OUTSIDE AIR TEMPERATURE	SUSP	SUSPENDED				
AVG	AVERAGE	EFW	EMERGENCY FACE WASH	HP	HORSEPOWER / HEAT PUMP	OC	ON CENTER	SV	STEAM VENT / SPECIAL VENT				
AVMS	AIR VOLUME MEASURING STATION	EG	EXHAUST GRILLE / ETHYLENE GLYCOL	HPR	HIGH PRESSURE CONDENSATE RETURN	OD	OUTSIDE DIAMETER / OVERFLOW DRAIN	SW	SWITCH / SPECIAL WASTE				
AW	ACID WASTE	HER	EMERGENCY HOSE REEL	HPS	HIGH PRESSURE STEAM / HIGH PRESSURE SODIUM	OFCI	OWNER FURNISHED CONTRACTOR INSTALLED	SWBD	SWITCHBOARD				
B	BOILER	ELEC	ELECTRIC	HR	HOSE / HOSE REEL	OFOI	OWNER FURNISHED OWNER INSTALLED	SWGR	SWITCHGEAR				
BC	BARE COPPER	ELEV	ELEVATION / ELEVATOR	HRC	HEAT RECOVERY COIL	OPER	OPERATOR	SYS	SYSTEM				
BCU	BLOWER COIL UNIT	EMER	EMERGENCY	HTR	HEATER	OPNG	OPENING	T	THERMOSTAT / THERMOMETER				
BDD	BACKDRAFT DAMPER	EMG	EXTRUDED METAL GRILLE	HV	HIGH VOLTAGE	OPP	OPPOSITE	TB	TERMINAL BOX				
BEP	BACKFLOW PREVENTER	ENCL	ENCLOSURE	HVAC	HEATING, VENTILATING, AND AIR CONDITIONING	OR	OPERATING ROOM	TCC	TEMPERATURE CONTROL CONTRACTOR				
BHP	BRAKE HOSEPOWER	ENTR	ENTERING	HW	HOT WATER	OSD	OPEN SITE DRAIN	TD	TRENCH DRAIN				
BI	BACKWARD INCLINED	EOC	EMERGENCY OXYGEN CONNECTION	HWC	HOT WATER CIRCULATION	P	PUMP / POLE / PNEUMATIC / PRESSURE	TDSH	TOTAL DISCHARGE HEAD				
BRK	BREAKER	EOH	END OF MAIN DRIP	HWCP	HOT WATER CIRCULATING PUMP	PB	PUSHBUTTON / PULL BOX	TDV	TRIPLE DUTY VALVE				
BL	BUILDING LINE	EP	ELECTRIC PNEUMATIC	HWP	HEATING HOT WATER PUMP	PC	PLUMBING CONTRACTOR / PERSONAL COMPUTER	TECH	TECHNOLOGY				
BLDG	BUILDING	EQA	EQUIPMENT AIR	HWR	HEATING HOT WATER RETURN	PCS	PATHOGEN CONTROL SYSTEM	TEL	TELECOMMUNICATION				
BO	ROOM OUTLET	EQAC	EQUIPMENT AIR COMPRESSOR	HWS	HEATING HOT WATER SUPPLY	PD	PRESSURE DROP / PERFORATED DIFFUSER	TEMP	TEMPERATURE				
B025	BULK OXYGEN SITE	EQAD	EQUIPMENT AIR DRYER	HX	HEAT EXCHANGER	PE	PNEUMATIC ELECTRIC	THW	TEMPERED HOT WATER				
BP	BRINE PUMP	EQH	EQUIPMENT AIR INTAKE	HZ	HERTZ	PF	PREFILTERS / POWER FACTOR	TLL	TEMPERATURE LOW LIMIT				
BR	BRANCH	EQU	EQUIPMENT	IA	INSTRUMENT AIR	PG	PROPYLENE GLYCOL	TMBH	TOTAL MBH				
BSS	BULK SALT STORAGE	EQV	EQUIPMENT VACUUM	IAC	INSTRUMENT AIR COMPRESSOR	PH	PHASE	TMH	TOP OF MANHOLE				
BT	BRINE TANK / BATH TUB	EQVP	EQUIPMENT VACUUM PUMP	IAD	INSTRUMENT AIR DRYER	PHC	PREHEAT COIL	TMV	THERMOSTATIC MIXING VALVE				
BTM	BOTTOM	EQVV	EQUIPMENT VACUUM VENT	IC	INTERCOMUNICATION	PHWST	PREHEAT WATER STORAGE TANK	TSP	TOTAL STATIC PRESSURE				
BTU	BRITISH THERMAL UNIT	ERP	ELECTRIC RADIANT PANEL	ID	INSIDE DIAMETER / DIMENSION	PV	POST INDICATOR VALVE	TV	TELEVISION				
BTUH	BTU PER HOUR	ES	EMERGENCY SHOWER	IFB	INTEGRAL FACE AND BYPASS	PL	PILOT LIGHT	TW	TEMPERED WATER				
C	CONDUIT	ESRW	EMERGENCY SHOWER & FACE WASH	IN	INCHES	PLT	PLASTER TRAP	TYP	TYPICAL				
CC	DEGREES CELSIUS	ESP	EXTERNAL STATIC PRESSURE / ELEVATOR SUMP PUMP	INCH	INCHES	PLM	PANELBOARD	UC	UNDER CARPET				
CA	COMPRESSED AIR	ET	EXPANSION TANK	INCL	INCLUDE	POC	POINT OF CONNECTION	UCV	UNDER CABBINET / UNDER COUNTER				
CAB	CABINET	ELH	ELECTRIC UNIT HEATER	INSUL	INSULATED	PPH	POUNDS PER HOUR	UH	UNIT HEATER				
CAP	CAPACITY	EW	ELECTRIC WATER COOLER	INT	INTERIOR	PPM	PARTS PER MILLION	UNO	UNLESS NOTED OTHERWISE				
CAV	CONSTANT AIR VOLUME	EWT	ENTERING WATER TEMPERATURE	INV	INVERT	PRD	PRESSURE RELIEF DOOR	UR	URINAL				
CB	CIRCUIT BREAKER	EX	EXPLOSION-PROOF	IPS	INTERNATIONAL PIPE SIZING	PREFAB	PREFABRICATED	UST	UNDERGROUND STORAGE TANK				
CC	COOLING COIL	EXH	EXHAUST	ISG	ISOLATED GROUND SURGE GUARD	PRES	PRESSURE	UV	ULTRA VIOLET LIGHT / UNIT VENTILATOR				
CC	CENTER TO CENTER	EXIST	EXISTING	ISO	ISOLATION	PRV	PRESSURE REDUCING / REGULATING VALVE	V	VENT / VOLT				
CCP	COOLING COIL PUMP	EXP	EXPANSION	JB	JUNCTION BOX	PSI	POUNDS PER SQUARE INCH	VAC	VACUUM				
CCTV	CLOSED CIRCUIT TELEVISION	EXT	EXTERIOR	JP	JOCKEY PUMP	PSIA	POUNDS PER SQUARE INCH ABSOLUTE	VAV	VARIABLE AIR VOLUME				
CENTRF	CENTRIFUGAL	°F	DEGREES FARENHEIT	JT	JOINT	PSIG	POUNDS PER SQUARE INCH GAUGE	VB	VACUUM BREAKER				
CF	CARBON FILTER	F&B	FACE & BYPASS	KAIC	KILO-AMPERE INTERRUPTING CAPACITY	PT	PNEUMATIC TUBE	VC	VACUUM CLEANING				
CFCI	CONTRACTOR FURNISHED / CONTRACTOR INSTALLED	F&T	FLOAT AND THERMOSTATIC TRAP	KEC	KITCHEN EQUIPMENT CONTRACTOR	PTS	PNEUMATIC TUBE STATION	VD	VOLUME DAMPER (MANUAL)				
CFM	CUBIC FEET PER MINUTE	FA	FIRE ALARM	KR	KRYPTON	PV	PLUG VALVE	VEL	VELOCITY				
OFOI	OWNER FURNISHED / OWNER INSTALLED	FSD	FIRE AND SMOKE DAMPER	KT	KITCHENETTE	PVC	POLYVINYL CHLORIDE	VFC	VARIABLE FREQUENCY CONTROLLER				
CH	CHILLER	FAPF	FIRE ALARM ANNUNCIATOR PANEL	KVA	KILOVOLT AMPERE	PW	PURE WATER / PART WINDING	VFD	VARIABLE FREQUENCY DRIVE				
CHWR	CHILLED WATER RETURN	FACP	FIRE ALARM CONTROL PANEL	KVAR	KILOVOLT AMPERE REACTIVE	PWP	PURE WATER PUMP	VH	VOLTMETER				
CHWS	CHILLED WATER SUPPLY	FAPS	FIRE ALARM POWER SUPPLY	KW	KILOWATT	PHR	PURE WATER RETURN / POWER	VOL	VOLUME				
CI	CAST IRON	FC	FLAT CABLE	L	LENGTH	PWS	PURE WATER SUPPLY	VP	VAPORPROOF				
CKT	CIRCUIT BREAKER	FCD	FLOOR CLEANOUT	LA	LAB AIR	PWT	PURE WATER TAP	VSC	VARIABLE SPEED CONTROLLER				
CL	CENTER LINE	FCU	FAN COIL UNIT	LAB	LABORATORY	PWST	PURE WATER STORAGE TANK	VSD	VARIABLE SPEED DRIVE				
CLG	CEILING	FD	FLOOR DRAIN / FIRE DAMPER	LAC	LAB AIR COMPRESSOR	RA	RETURN AIR / RELIEF AIR	VTR	VENT THROUGH ROOF				
CO	CLEAN OUT / CARBON MONOXIDE / CEILING OUTLET	FDC	FIRE DEPARTMENT CONNECTION	LAD	LAB AIR DRYER	RACU	ROOM AIR CONDITIONING UNIT	VV	VACUUM VENT				
CO2	CARBON DIOXIDE	FF	FAN FILTERS	LAN	LOCAL AREA NETWORK	RAD	RADIATED	V (CHEM)	VENT - CHEMICAL				
COL	COLUMN	FFC	FOOD FACILITY CONTRACTOR	LAT	LEAVING AIR TEMPERATURE	RAT	RETURN AIR TEMPERATURE	W	WASTE / WATTS / WIDTH				
CO2M	CARBON DIOXIDE MANIFOLD	FFE	FINISHED FLOOR ELEVATION	LAV	LAVATORY	RB	REFRIGERATOR BOX	WAGD	WASTE ANESTHESIA GAS DISPOSAL				
DCOMM	COMMUNICATION	FFS	FOOD FACILITY SUPPLIER	LBC	LINEAR BAR DIFFUSER	RD	ROOF DRAIN	WAGDP	WASTE ANESTHESIA GAS DISPOSAL PUMP				
COMP	COMPRESSOR	FH	FIRE HOSE / FUME HOOD	LB(S)	POUND(S)	RH	REHEAT	WB	WET BULB / WASHER SUPPLY BOX				
CONC	CONCRETE	FHC	FIRE HOSE CABINET	LD	LINEAR DIFFUSER	REC	RECEIVER / RECEPTACLE	WC	WATER CLOSET				
CONN	CONNECTION	FIN	FINISH	LF	LINEAR FEET	RECR	RECIRCULATING	WI	WITH				
CONST	CONSTRUCTION	FIXT	FIXTURE	LFD	LAMINAR FLOW DIFFUSER	REF	REFRIGERATOR	WO	WALL OUTLET				
CONT	CONTINUOUS	FLA	FULL LOAD AMPS	LFT	LEAVING FLUID TEMPERATURE	RENF	REINFORCED	WIO	WITHOUT				
CONTR	CONTRACTOR	FLEX	FLEXIBLE CONNECTION	LOC	LOCATION	R	RETURN AIR FAN	WIPD	WATER FLOW MEASURING DEVICE				
CP	CONDENSATE PUMP	FLR	FLOOR	LP	LIQUID PROPANE (GAS)	RG	RETURN GRILLE	WIC	WATER GAUGE				
CPD	CONDENSATE PUMP DISCHARGE	FLUOR	FLUORESCENT	LPBS	LIQUID PROPANE BLENDING STATION	RGIP	REMOTE GROUND INDICATING PANEL	WGT	WEIGHT				
CR	CRITICAL	FMI	FUEL MONITOR	LPR	LOW PRESSURE CONDENSATE RETURN	RH	RELIEF HOOD / RELATIVE HUMIDITY / ROOF HYDRANT	WH	WALL HYDRANT				
CT	CURRENT TRANSFORMER	FO	FUEL OIL	LPS	LOW PRESSURE STEAM	RHC	REHEAT COIL / ROOF HOSE CONNECTION	WM	WATER METER				
CTFS	COOLING TOWER FILTRATION SYSTEM	FODT	FUEL OIL DAY TANK	LPT	LIQUID PROPANE TANK	RLA	RUNNING LOAD AMPS	WP	WEATHERPROOF				
CU	COPPER	FOM	FUEL OIL MONITOR	LS	LIFE SAFETY	RM	ROOM	WPD	WATER PRESSURE DROP				
CUN	CABINET UNIT HEATER	FOP	FUEL OIL PUMP	LT	LIGHT / LAUNDRY DRAIN TROUGH	ROM	REVERSE OSMOSIS MACHINE	WS	WATER SOFTENER				
CW	COLD WATER	FOR	FUEL OIL RETURN	LTG	LIGHTING	ROP	REVERSE OSMOSIS PUMP	WT	WEIGHT				
CWM	COLD WATER MAKE-UP	FOS	FUEL OIL SUPPLY	LVG	LEAVING	ROR	REVERSE OSMOSIS RETURN	WTR	WATER				
CHWP	CHILLED WATER PUMP	FOST	FUEL OIL STORAGE TANK	LVP	LAB VACUUM / LOW VOLTAGE	ROS	REVERSE OSMOSIS SUPPLY	XE	XENON				
CWR	CONDENSER WATER RETURN	FOTS	FUEL OIL TREATMENT SYSTEM	LVP	LAB VACUUM PUMP	ROST	REVERSE OSMOSIS STORAGE TANK	XFMR	TRANSFORMER				
CWS	CONDENSER WATER SUPPLY	FOTS	FUEL OIL TANK	LW	LAB WATER	RP	RADIANT PANELS	YH	YARD HYDRANT				
D	DRAWING	FOW	FUEL OIL VENT	LWT	LEAVING WATER TEMPERATURE	MA	MEDICAL AIR	Z	IMPEDANCE				
DB	DEGREES (DRY BULB) DIRECT BURIAL / DIALYSIS BOX	FP	FIRE PROTECTION / FIRE PUMP	MA	MEDICAL AIR	MAC	MEDICAL AIR COMPRESSOR	ZVB	ZONE VALVE BOX				
DC	DUCT COIL / DIRECT CURRENT	FPB	FAN POWERED BOX	MAI	MEDICAL AIR INTAKE	MAI	MEDICAL AIR INTAKE	#	NUMBER / POUND				
DCV	DOUBLE CHECK VALVE	FPC	FIRE PROTECTION CONTRACTOR	MAM	MEDICAL AIR MANIFOLD	REQD	REQUIRED	Δ	DELTA / DIFFERENCE				
DOWBP	DOMESTIC COLD WATER BOOSTER PUMP	FPM	FEET PER MINUTE	MAP	MASTER ALARM PANEL	RV	ROOF VENTILATOR	°	DEGREE				
DD	DUAL DUCT	FPS	FEET PER SECOND	MAT	MIXED AIR TEMPERATURE	S	SANITARY	'	FEET				
DDC	DIRECT DIGITAL CONTROL	FSS	FUSED SAFETY SWITCH	MATV	MASTER ANTENNA TELEVISION	S (CHEM)	SANITARY - CHEMICAL	*	INCHES				
DE	DEAERATOR	FT	FEET / FLASH TANK	MAU	MAKE UP AIR UNIT	S (GREASE)	SANITARY - GREASE	%	PERCENT				
DEFL	DEFLECTION	FTG	FOOTING / FITTING	MB	MOP BASIN								
DEG	DEGREES CELSIUS	FTR	FIN TUBE RADIATION										
DEPT	DEPARTMENT	FVR	FILMVIEWER										
DF	DRINKING FOUNTAIN												

- GENERAL NOTES
1. HEATING, VENTILATING, AIR CONDITIONING, AND ELECTRICAL DESIGNS ARE BASED ON THE REQUIREMENTS FOR THE SPECIFIED EQUIPMENT MANUFACTURER. CONDUITS, DISCONNECTS, BREAKERS, FUSES, AND WIRE SIZES ARE SELECTED ON THE BASIS OF SPECIFIED EQUIPMENT MANUFACTURER. INCREASED CURRENT REQUIREMENTS NECESSITATING LARGER WIRE, BREAKERS, FUSES, SWITCHES, ETC. TO ACCOMMODATE ANY ALTERNATE OR SUBSTITUTE MANUFACTURER'S EQUIPMENT OTHER THAN AS SHOWN ON DRAWINGS OR SCHEDULES SHALL BE PROVIDED WITHOUT INCREASE IN CONTRACT PRICE BY THE CONTRACTOR FURNISHING EQUIPMENT. WIRE SIZES ARE SELECTED ON THE BASIS OF SPECIFIED EQUIPMENT.

2. IF THE EXISTING ROOF IS UNDER WARRANTY, ALL CUTTING, PATCHING AND RESEALING SHALL BE PERFORMED BY A WARRANTY CERTIFIED INSTALLER TO MAINTAIN THE WARRANTY. CONTRACTOR SHALL EXERCISE DUE CAUTION WHEN WORKING ON ROOF AND SHALL COMPLY WITH WARRANTY RECOMMENDED METHODS AND MATERIALS TO PROTECT THE ROOF FROM DAMAGE. CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIR OF ANY DAMAGE TO THE ROOF PER THE REQUIREMENTS. COORDINATE WITH OWNER / ARCHITECT TO DETERMINE ANY WARRANTY REQUIREMENTS.

3. CONTRACTOR SHALL SURVEY ALL EXISTING MECHANICAL EQUIPMENT AND SYSTEMS PRIOR TO WORK OPERATIONS INDICATED ON PLANS TO NOT DISTURB EXISTING SYSTEMS TO REMAIN.

4. ALL WORK DEBRIS SHALL BE