


PANELBOARD: MDP LOCATION: NON-HEATED... VOLTAGE: 120/240 V, 1 ø 3 W. MOUNTING: SURFACE NEMA 1 A.I.C. RATING: 35,000 AMPS SYMMETRICAL. MAIN DEVICE: 600.0 A MLO SPECIAL: BUS AMPS: 600 AMPS FED FROM: UTILITY

PANELBOARD: LA LOCATION: NON-HEATED... VOLTAGE: 120/240 V, 1 ø 3 W. MOUNTING: SURFACE NEMA 1 A.I.C. RATING: 35,000 AMPS SYMMETRICAL. MAIN DEVICE: 200.0 A MLO SPECIAL: BUS AMPS: 200 AMPS FED FROM: MDP

PANELBOARD: LO LOCATION: CLOSET 107 VOLTAGE: 120/240 V, 1 ø 3 W. MOUNTING: SURFACE NEMA 1 A.I.C. RATING: 25,000 AMPS SYMMETRICAL. MAIN DEVICE: 200.0 A MLO SPECIAL: BUS AMPS: 200 AMPS FED FROM: MDP



PROJECT NUMBER: 25-040

REVISIONS table with columns for NO., DATE, and ISSUE.

COMcheck Software Version 4.1.5.5 Interior Lighting Compliance Certificate. Project Information: Energy Code: 2015 IECC, Project Title: Drywall Warehouse Highway 81, Project Type: New Construction. Construction Site: 257 Highway 81, Oxford, GA 30054. Designer/Contractor: Electrical Design Consultants, 175 New Street, Suite 1, Macon, GA 31201. Credits: 1.0 Required, 1.0 Proposed, 1.0 credit. Allowed Interior Lighting Power table and Proposed Interior Lighting Power table included.

COMcheck Software Version 4.1.5.5 Exterior Lighting Compliance Certificate. Project Information: Energy Code: 2015 IECC, Project Title: Drywall Warehouse Highway 81, Project Type: New Construction, Exterior Lighting Zone: 1 (Developed area on forest land (LZ1)). Construction Site: 257 Highway 81, Oxford, GA 30054. Designer/Contractor: Electrical Design Consultants, 175 New Street, Suite 1, Macon, GA 31201. Allowed Exterior Lighting Power table and Proposed Exterior Lighting Power table included.

DRYWALL WAREHOUSE HWY 81

ELECTRICAL SCHEDULES

E-502 ISSUED FOR CONSTRUCTION

