

SECTION 087100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes commercial door hardware for the following:
 - 1. Swinging doors.
 - 2. Sliding doors.
 - 3. Other doors to the extent indicated.
- B. Door hardware includes, but is not necessarily limited to, the following:
 - 1. Mechanical door hardware.
 - 2. Electromechanical door hardware.
 - 3. Cylinders specified for doors in other sections.
- C. Related Sections:
 - 1. Division 01 Section "General Conditions".
 - 2. Division 06 Section "Rough Carpentry".
 - 3. Division 06 Section "Interior Finish Carpentry".
 - 4. Division 08 Section "Hollow Metal Frames".
 - 5. Division 08 Section "Flush Wood Doors".
 - 6. Division 08 Section "Aluminum-Framed Entrances and Storefronts".
 - 7. Division 26 Section "Electrical"
- D. Codes and References: Comply with the version adopted by the Authority Having Jurisdiction.
 - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
 - 2. ICC/IBC - International Building Code.
 - 3. NFPA 70 - National Electrical Code.
 - 4. NFPA 80 - Fire Doors and Windows.
 - 5. NFPA 101 - Life Safety Code.
 - 6. NFPA 105 - Installation of Smoke Door Assemblies.
 - 7. State Building Codes, Local Amendments.
- E. Standards: All hardware specified herein shall comply with the following industry standards as applicable. Any undated reference to a standard shall be interpreted as referring to the latest edition of that standard:

1. ANSI/BHMA Certified Product Standards - A156 Series.
2. UL10C - Positive Pressure Fire Tests of Door Assemblies.
3. ANSI/UL 294 - Access Control System Units.
4. UL 305 - Panic Hardware.
5. ANSI/UL 437- Key Locks.

1.3 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing, fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
 1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
 3. Content: Include the following information:
 - a. Type, style, function, size, label, hand, and finish of each door hardware item.
 - b. Manufacturer of each item.
 - c. Fastenings and other pertinent information.
 - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
 - e. Explanation of abbreviations, symbols, and codes contained in schedule.
 - f. Mounting locations for door hardware.
 - g. Door and frame sizes and materials.
 - h. Warranty information for each product.
 4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.
- C. Shop Drawings: Details of electrified access control hardware indicating the following:
 1. Wiring Diagrams: Upon receipt of approved schedules, submit detailed system wiring diagrams for power, signaling, monitoring, communication, and control of the access control system electrified hardware. Differentiate between manufacturer-installed and field-installed wiring. Include the following:

- a. Elevation diagram of each unique access controlled opening showing location and interconnection of major system components with respect to their placement in the respective door openings.
 - b. Complete (risers, point-to-point) access control system block wiring diagrams.
 - c. Wiring instructions for each electronic component scheduled herein.
2. Electrical Coordination: Coordinate with related sections the voltages and wiring details required at electrically controlled and operated hardware openings.
- D. Keying Schedule: After a keying meeting with the owner has taken place prepare a separate keying schedule detailing final instructions. Submit the keying schedule in electronic format. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner must approve submitted keying schedule prior to the ordering of permanent cylinders/cores.
- E. Informational Submittals:
 1. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.

1.4 CLOSEOUT SUBMITTALS

- A. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Procedures.
- B. Door Opening Field Inspection (Punch Report): Provide Door Opening Field Inspection Report as required by Division 01 upon completion of opening inspection, organized by door identifier (mark), and including; individually identified deficiencies associated with assembly components, related opening images and video recordings, and opening remarks.
- C. Fire Door Assembly Inspection: Provide Fire Door Assembly Inspection Report upon completion of fire door inspection as required by Division 01 and NFPA 80, section 5.2.2.4.
- D. Protective Door Assembly Inspection: Provide Protective Door Assembly Inspection Report upon final completion of non-rated and fire rated egress door inspection as required by Division 01 and NFPA 80, section 5.2.2.4.

1.5 QUALITY ASSURANCE

- A. Manufacturers Qualifications: Engage qualified manufacturers with a minimum 5 years of documented experience in producing hardware and equipment similar to that indicated for this Project and that have a proven record of successful in-service performance.
- B. Certified Products: Where specified, products must maintain a current listing in the Builders Hardware Manufacturers Association (BHMA) Certified Products Directory (CPD).

- C. Installer Qualifications: A minimum 3 years documented experience installing both standard and electrified door hardware similar in material, design, and extent to that indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.
- D. Door Hardware Supplier Qualifications: Experienced commercial door hardware distributors with a minimum 5 years documented experience supplying both mechanical and electromechanical hardware installations comparable in material, design, and extent to that indicated for this Project. Supplier recognized as a factory direct distributor by the manufacturers of the primary materials with a warehousing facility in Project's vicinity. Supplier to have on staff a certified Architectural Hardware Consultant (AHC) available during the course of the Work to consult with Contractor, Architect, and Owner concerning both standard and electromechanical door hardware and keying.
- E. Source Limitations: Obtain each type and variety of door hardware specified in this section from a single source unless otherwise indicated.
 - 1. Electrified modifications or enhancements made to a source manufacturer's product line by a secondary or third party source will not be accepted.
 - 2. Provide electromechanical door hardware from the same manufacturer as mechanical door hardware, unless otherwise indicated.
- F. Each unit to bear third party permanent label indicating compliance with the referenced testing standards.
- G. Keying Conference: Conduct conference to comply with requirements in Division 01 Section "Project Meetings." Keying conference to incorporate the following criteria into the final keying schedule document:
 - 1. Function of building, purpose of each area and degree of security required.
 - 2. Plans for existing and future key system expansion.
 - 3. Requirements for key control storage and software.
 - 4. Installation of permanent keys, cylinder cores and software.
 - 5. Address and requirements for delivery of keys.
- H. Pre-Submittal Conference: Conduct coordination conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier(s), Installer(s), and Contractor(s) to review proper methods and the procedures for receiving, handling, and installing door hardware.
 - 1. Prior to installation of door hardware, conduct a project specific training meeting to instruct the installing contractors' personnel on the proper installation and adjustment of their respective products. Product training to be attended by installers of door hardware (including electromechanical hardware) for aluminum, hollow metal and wood doors. Training will include the use of installation manuals, hardware schedules, templates and physical product samples as required.
 - 2. Inspect and discuss electrical roughing-in, power supply connections, and other preparatory work performed by other trades.
 - 3. Review sequence of operation narratives for each unique access controlled opening.
 - 4. Review and finalize construction schedule and verify availability of materials.

5. Review the required inspecting, testing, commissioning, and demonstration procedures

- I. At completion of installation, provide written documentation that components were applied according to manufacturer's instructions and recommendations and according to approved schedule.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.
- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

1.7 COORDINATION

- A. Templates: Obtain and distribute to the parties involved templates for doors, frames, and other work specified to be factory prepared for installing standard and electrified hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing hardware to comply with indicated requirements.
- B. Door and Frame Preparation: Doors and corresponding frames are to be prepared, reinforced and pre-wired (if applicable) to receive the installation of the specified electrified, monitoring, signaling and access control system hardware without additional in-field modifications.

1.8 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.
- B. Warranty Period: Written warranty, executed by manufacturer(s), agreeing to repair or replace components of standard and electrified door hardware that fails in materials or workmanship within specified warranty period after final acceptance by the Owner. Failures include, but are not limited to, the following:
 - 1. Structural failures including excessive deflection, cracking, or breakage.
 - 2. Faulty operation of the hardware.
 - 3. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
 - 4. Electrical component defects and failures within the systems operation.

- C. Warranty Period: Unless otherwise indicated, warranty shall be one year from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Hardware shall not have any visible manufacturer names on exposed materials, except cylinders, when the door is in a closed position.

2.2 BUTT HINGES

- A. Hinges: ANSI/BHMA A156.1 butt hinges with number of hinge knuckles and other options as specified in the Door Hardware Sets.

1. Quantity: Provide the following hinge quantity:
 - a. Two Hinges: For doors with heights up to 60 inches.
 - b. Three Hinges: For doors with heights 61 to 90 inches.
 - c. Four Hinges: For doors with heights 91 to 120 inches.
 - d. For doors with heights more than 120 inches, provide 4 hinges, plus 1 hinge for every 30 inches of door height greater than 120 inches.
2. Hinge Size: Provide the following, unless otherwise indicated, with hinge widths sized for door thickness and clearances required:
 - a. Widths up to 3'0": 4-1/2" standard or heavy weight as specified.
 - b. Sizes from 3'1" to 4'0": 5" standard or heavy weight as specified.
3. Hinge Weight and Base Material: Unless otherwise indicated, provide the following:
 - a. Exterior Doors: Heavy weight, non-ferrous, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate standard weight.
 - b. Interior Doors: Standard weight, steel, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate heavy weight.
4. Hinge Options: Comply with the following:
 - a. Non-removable Pins: With the exception of electric through wire hinges, provide set screw in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while door is closed; for all out-swinging lockable doors.
5. Manufacturers:
 - a. McKinney (MK) - TA/T4A Series, 5-knuckle.

2.3 CONTINUOUS HINGES

- A. Continuous Geared Hinges: ANSI/BHMA A156.26 Grade 1-600 continuous geared hinge. with minimum 0.120-inch thick extruded 6063-T6 aluminum alloy hinge leaves and a minimum overall width of 4 inches. Hinges are non-handed, reversible and fabricated to template screw locations. Factory trim hinges to suit door height and prepare for electrical cut-outs.
 - 1. Manufacturers:
 - a. Pemko (PE).

2.4 POWER TRANSFER DEVICES

- A. Concealed Quick Connect Electric Power Transfers: Provide concealed wiring pathway housing mortised into the door and frame for low voltage electrified door hardware. Furnish with Molex™ standardized plug connectors and sufficient number of concealed wires (up to 12) to accommodate the electrified functions specified in the Door Hardware Sets. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies. Wire nut connections are not acceptable.
 - 1. Manufacturers:
 - a. Pemko (PE) - EL-CEPT Series.
 - b. Securitron (SU) - EL-CEPT Series.
- B. Electric Door Wire Harnesses: Provide electric/data transfer wiring harnesses with standardized plug connectors to accommodate up to twelve (12) wires. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies. Provide sufficient number and type of concealed wires to accommodate electric function of specified hardware. Provide a connector for through-door electronic locking devices and from hinge to junction box above the opening. Wire nut connections are not acceptable. Determine the length required for each electrified hardware component for the door type, size and construction, minimum of two per electrified opening.
 - 1. Provide one each of the following tools as part of the base bid contract:
 - a. McKinney (MK) - Electrical Connecting Kit: QC-R001.
 - b. McKinney (MK) - Connector Hand Tool: QC-R003.
 - 2. Manufacturers:
 - a. McKinney (MK) - QC-C Series.

2.5 DOOR OPERATING TRIM

- A. Flush Bolts and Surface Bolts: Provide products conforming to ANSI/BHMA A156.3 and A156.16, Grade 1.

1. Flush bolts to be furnished with top rod of sufficient length to allow bolt retraction device location approximately six feet from the floor.
 2. Furnish dust proof strikes for bottom bolts.
 3. Surface bolts to be minimum 8" in length and U.L. listed for labeled fire doors and U.L. listed for windstorm components where applicable.
 4. Provide related accessories (mounting brackets, strikes, coordinators, etc.) as required for appropriate installation and operation.
 5. Manufacturers:
 - a. Rockwood (RO).
- B. Coordinators: ANSI/BHMA A156.3 door coordinators consisting of active-leaf, hold-open lever and inactive-leaf release trigger. Model as indicated in hardware sets.
1. Manufacturers:
 - a. Rockwood (RO).
- C. Door Push Plates and Pulls: ANSI/BHMA A156.6 door pushes and pull units of type and design specified in the Hardware Sets. Coordinate and provide proper width and height as required where conflicting hardware dictates.
1. Push/Pull Plates: Minimum .050 inch thick, size as indicated in hardware sets, with beveled edges, secured with exposed screws unless otherwise indicated.
 2. Door Pull and Push Bar Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door unless otherwise indicated.
 3. Offset Pull Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door and offset of 90 degrees unless otherwise indicated.
 4. Pulls shall be provided with a 10" clearance from the finished floor on the push side to accommodate wheelchair accessibility.
 5. Fasteners: Provide manufacturer's designated fastener type as indicated in Hardware Sets. When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.
 6. Manufacturers:
 - a. Rockwood (RO).
- D. Single Motion Flat Latching Devices: Single motion flat latching devices with integrated locking pull, designed for outswing door applications.
1. Provide latching devices with functions and features as follows:
 - a. ADA-compliant available, meeting California Building Code (2019) Section 11B-309.4.
 - b. Outswing applications only with single motion egress.
 - c. Engraved "PUSH" area on egress side.
 - d. Optional dogging to allow latch to remain retracted for free operation.

2. Manufacturers:
 - a. Rockwood (RO) - SMU9000 Series.
 - b. No Substitution.

2.6 CYLINDERS AND KEYING

- A. General: Cylinder manufacturer to have minimum (10) years experience designing secured master key systems and have on record a published security keying system policy.
- B. Cylinder Types: Original manufacturer cylinders able to supply the following cylinder formats and types:
 1. Threaded mortise cylinders with rings and cams to suit hardware application.
 2. Rim cylinders with back plate, flat-type vertical or horizontal tailpiece, and raised trim ring.
 3. Bored or cylindrical lock cylinders with tailpieces as required to suit locks.
 4. Tubular deadlocks and other auxiliary locks.
 5. Mortise and rim cylinder collars to be solid and recessed to allow the cylinder face to be flush and be free spinning with matching finishes.
 6. Keyway: Match Facility Standard.
- C. Keying System: Each type of lock and cylinders to be factory keyed.
 1. Supplier shall conduct a "Keying Conference" to define and document keying system instructions and requirements.
 2. Furnish factory cut, nickel-silver large bow permanently inscribed with a visual key control number as directed by Owner.
 3. Existing System: Field verify and key cylinders to match Owner's existing system.
- D. Key Quantity: Provide the following minimum number of keys:
 1. Change Keys per Cylinder: Two (2)
 2. Master Keys (per Master Key Level/Group): Five (5).
- E. Key Registration List (Bitting List):
 1. Provide keying transcript list to Owner's representative in the proper format for importing into key control software.
 2. Provide transcript list in writing or electronic file as directed by the Owner.

2.7 KEY CONTROL

- P. Electronic Key Management System: Provide an electronic key control system with Stand-alone Plug and Play features including advanced RFID technology. Touchscreen interface with PIN access for keys individually locked in place. Minimum 1,000 system users and 21 iFobs for locking receptors. System shall have a minimum 250,000 audit events screen displayed or ability to be exported via USB port.

1. Manufacturers:
 - a. Medeco (MC).

2.8 MORTISE LOCKS AND LATCHING DEVICES

- A. Mortise Locksets, Grade 1 (Heavy Duty): Provide ANSI/BHMA A156.13, Series 1000, Operational Grade 1 Certified Products Directory (CPD) listed mortise locksets. Listed manufacturers shall meet all functions and features as specified herein.

1. Manufacturers:
 - a. Sargent Manufacturing (SA) - 8200 Series.
 - b. No Substitution.

2.9 LOCK AND LATCH STRIKES

- A. Strikes: Provide manufacturer's standard strike with strike box for each latch or lock bolt, with curved lip extended to protect frame, finished to match door hardware set, unless otherwise indicated, and as follows:

1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
3. Aluminum-Frame Strike Box: Provide manufacturer's special strike box fabricated for aluminum framing.
4. Double-lipped strikes: For locks at double acting doors. Furnish with retractable stop for rescue hardware applications.

- B. Standards: Comply with the following:

1. Strikes for Mortise Locks and Latches: BHMA A156.13.
2. Strikes for Bored Locks and Latches: BHMA A156.2.
3. Strikes for Auxiliary Deadlocks: BHMA A156.36.
4. Dustproof Strikes: BHMA A156.16.

2.10 CONVENTIONAL EXIT DEVICES

- A. General Requirements: All exit devices specified herein shall meet or exceed the following criteria:

1. Exit devices shall have a five-year warranty.
2. At doors not requiring a fire rating, provide devices complying with NFPA 101 and listed and labeled for "Panic Hardware" according to UL305. Provide proper fasteners as required by manufacturer including sex nuts and bolts at openings specified in the Hardware Sets.
3. Where exit devices are required on fire rated doors, provide devices complying with NFPA 80 and with UL labeling indicating "Fire Exit Hardware". Provide devices with the proper

- fasteners for installation as tested and listed by UL. Consult manufacturer's catalog and template book for specific requirements.
4. Except on fire rated doors, provide exit devices with hex key dogging device to hold the pushbar and latch in a retracted position. Provide optional keyed cylinder dogging on devices where specified in Hardware Sets.
 5. Devices must fit flat against the door face with no gap that permits unauthorized dogging of the push bar. The addition of filler strips is required in any case where the door light extends behind the device as in a full glass configuration.
 6. Lever Operating Trim: Where exit devices require lever trim, furnish manufacturer's heavy duty escutcheon trim with threaded studs for thru-bolts.
 - a. Lock Trim Design: As indicated in Hardware Sets, provide finishes and designs to match that of the specified locksets.
 - b. Where function of exit device requires a cylinder, provide a cylinder (Rim or Mortise) as specified in Hardware Sets.
 7. Vertical Rod Exit Devices: Where surface or concealed vertical rod exit devices are used at interior openings, provide as less bottom rod (LBR) unless otherwise indicated. Provide dust proof strikes where thermal pins are required to project into the floor.
 8. Narrow Stile Applications: At doors constructed with narrow stiles, or as specified in Hardware Sets, provide devices designed for maximum 2" wide stiles.
 9. Dummy Push Bar: Nonfunctioning push bar matching functional push bar.
 10. Rail Sizing: Provide exit device rails factory sized for proper door width application.
 11. Through Bolt Installation: For exit devices and trim as indicated in Door Hardware Sets.
- B. Conventional Push Rail Exit Devices (Heavy Duty): ANSI/BHMA A156.3, Grade 1 Certified Products Directory (CPD) listed exit devices. Listed manufacturers shall meet all functions and features as specified herein.
1. Provide exit devices with functions and features as follows:
 - a. Where required by code, provide knurling or abrasive coating on all levers leading to hazardous areas.
 - b. Meets UL and CUL Standard 10C Positive Pressure, Fire Test of Door Assemblies with levers that meet A117.1 Accessibility Code.
 - c. No catch points: addition of applied deflectors or other added components are not allowed.
 - d. No visible plastic.
 - e. Heavy duty end caps with flush and overlapping options made of stainless steel, brass, or bronze with architectural finishes.
 - f. Constructed of all stainless steel.
 - g. Stainless steel pullman type latch with deadlock feature.
 - h. Narrow or wide style exterior trim as specified in the hardware sets.
 - i. Center case adjustability on concealed vertical rod exit devices; single operation with hex key individually adjusts top or bottom latches. No retainer screws or clips required to maintain adjustment.
 - j. Ten-year limited warranty for mechanical features.

2. Manufacturers:

- a. Sargent Manufacturing (SA) - PE80 Series.
- b. No Substitution.

2.11 SURFACE DOOR CLOSERS

A. All door closers specified herein shall meet or exceed the following criteria:

1. General: Door closers to be from one manufacturer, matching in design and style, with the same type door preparations and templates regardless of application or spring size. Closers to be non-handed with full sized covers.
2. Standards: Closers to comply with UL-10C for Positive Pressure Fire Test and be U.L. listed for use of fire rated doors.
3. Size of Units: Comply with manufacturer's written recommendations for sizing of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Where closers are indicated for doors required to be accessible to the Americans with Disabilities Act, provide units complying with ANSI ICC/A117.1.
4. Closer Arms: Provide heavy duty, forged steel closer arms unless otherwise indicated in Hardware Sets.
5. Closers shall not be installed on exterior or corridor side of doors; where possible install closers on door for optimum aesthetics.
6. Closer Accessories: Provide door closer accessories including custom templates, special mounting brackets, spacers and drop plates as required for proper installation. Provide through-bolt and security type fasteners as specified in the hardware sets.

B. Door Closers, Surface Mounted (Large Body Cast Iron): ANSI/BHMA A156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted, heavy duty door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron body construction, with adjustable backcheck and separate non-critical valves for closing sweep and latch speed control.

1. Large body cast iron surface mounted door closers shall have a 30-year warranty.
2. Manufacturers:
 - a. Sargent Manufacturing (SA) - 281 Series.
 - b. No Substitution.

C. Door Closers, Surface Mounted (Utility Grade, Chiming): ANSI/BHMA 156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted, utility grade door closers with built in chime that is activated by the rotation of the closer pinion. Closers to be rack and pinion type, cast aluminum case construction, with adjustable backcheck, closing sweep, and latch speed control valves and complete spring power adjustment, sizes 1 thru 6. Provide closer standard packed for regular, top-jamb, and parallel arm type mounting applications.

1. Manufacturers:

- a. Norton Rixson (NO) - Norbell Series.
- b. No Substitution.

2.12 ARCHITECTURAL TRIM AND ACCESSORIES

- A. Door, Frame and Wall Protective Trim: ANSI/BHMA A156.6, protective products as specified in the hardware sets. Door protection plates shall be not more than 2" less than door width on stop side and 1" less door width on the pull side or on stop side of pairs of doors. Listed manufacturers shall meet all functions and features as specified herein.
 - 1. Provide protective trim with functions and features as follows:
 - a. Meets ADA requirements for smooth bottom door surfaces.
 - b. UL Classified options for use on fire-rated doors up to 3 hours.
 - c. Fabricated from stainless steel, brass, bronze, aluminum, or high-impact plastic.
 - d. Available in a variety of sizes, finishes, and profiles to suit aesthetic and functional requirements.
 - e. Designed to protect doors, frames, and adjacent walls from damage due to impact, abrasion, or traffic.
 - f. Fasteners included; adhesive-backed options available for select models.
 - g. Ten-year limited warranty.
 - 2. Manufacturers:
 - a. Rockwood (RO).

2.13 DOOR STOPS AND HOLDERS

- A. Door Stops and Bumpers: ANSI/BHMA A156.16, Grade 1 door stops and wall bumpers. Provide wall bumpers, either convex or concave types with anchorage as indicated, unless floor or other types of door stops are specified in Hardware Sets. Do not mount floor stops where they will impede traffic. Where floor or wall bumpers are not appropriate, provide overhead type stops and holders.
 - 1. Manufacturers:
 - a. Rockwood (RO).
- B. Overhead Door Stops and Holders: ANSI/BHMA A156.8, Grade 1 Certified Products Directory (CPD) listed overhead stops and holders to be surface or concealed types as indicated in Hardware Sets. Track, slide, arm and jamb bracket to be constructed of extruded bronze and shock absorber spring of heavy tempered steel. Provide non-handed design with mounting brackets as required for proper operation and function.
 - 1. Manufacturers:
 - a. Norton Rixson (NO).
 - b. Rockwood (RO).

- c. Sargent Manufacturing (SA).

2.14 ARCHITECTURAL SEALS

- A. General: Thresholds, weatherstripping, and gasket seals to be of type and design as specified below or in the Hardware Sets. Provide continuous weatherstrip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated. At exterior applications provide non-corrosive fasteners and elsewhere where indicated.
- B. Smoke Labeled Gasketing: Assemblies complying with NFPA 105 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for smoke control ratings indicated, based on testing according to UL 1784.
 - 1. Provide smoke labeled perimeter gasketing at all smoke labeled openings.
- C. Fire Labeled Gasketing: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to UL-10C.
 - 1. Provide intumescent seals as indicated to meet UL10C Standard for Positive Pressure Fire Tests of Door Assemblies, and NFPA 252, Standard Methods of Fire Tests of Door Assemblies.
- D. Sound-Rated Gasketing: Assemblies that are listed and labeled by a testing and inspecting agency, for sound ratings indicated.
- E. Replaceable Seal Strips: Provide only those units where resilient or flexible seal strips are easily replaceable and readily available from stocks maintained by manufacturer.
- F. Manufacturers:
 - 1. Pemko (PE).

2.15 ELECTRONIC ACCESSORIES

- A. Networked Proximity Card Readers: Card readers to support HID 125 kHz proximity technology and interface with the access control reader modules and door control hardware devices as specified. Card readers to meet the following, minimum, design and performance specifications.
 - 1. Reader to operate on 12VDC or 5VDC power from the reader I/O modules at a maximum current rating of 150 mA per reader.
 - 2. Reader to be weatherproof type when installed in exterior or other wet environments.
 - 3. Reader to communicate with the reader I/O modules using industry standard Wiegand protocol interface.
 - 4. Reader to have multi-color LED display and audible status indications.
 - 5. Reader type and model to meet the design and mounting applications needs of each entry point as indicated on the drawings.

6. Manufacturers (125 kHz Proximity):
 - a. Corbin Russwin Hardware (RU) - 752F909/751F929 Series.
 - b. Sargent Manufacturing (SA) - 4302/4304 Series.
- B. Networked Contactless Smart Card Readers: Contactless smart cards reader to securely read access control data from 13.56 MHz contactless smart cards. The contactless smart card reader is designed for use in access control applications by providing:
 1. Secure access control data exchange between the smart card and the reader utilizing key diversification and mutual authentication routines.
 2. Contactless smart card reader to be designed for low current operation to enable migration from most legacy proximity applications without the need to replace existing access control panels and/or power supplies. Operating voltage: 5-16 VDC. Current requirements: 55 mA Avg, 116 mA Peak at 12 VDC.
 3. Universal compatibility with most access control systems and backwards compatibility with legacy 125 KHz proximity access control formats.
 4. Product construction suitable for both indoor and outdoor applications.
 5. Customizable behavior for indicator lights and audible tones.
 6. Manufacturers (13.56 MHz iClass):
 - a. Corbin Russwin Hardware (RU) - 744F709/744F719 Series.
 - b. Sargent Manufacturing (SA) - 6100/6120 Series.
- C. Wireless Card Readers: Card readers to support HID 125 kHz proximity technology or 13.56 MHz contactless smart cards as specified in the hardware sets. Card readers to meet the following minimum design and performance specifications.
 1. Reader to wirelessly operate on one 3V CR2 lithium battery.
 2. Reader to be suitable for outdoor use.
 3. Contactless smart card versions to be compatible with the following technologies: iCLASS, iCLASS Seos, iCLASS SE, ISO1443B UID, Mifare, Mifare Plus, Desfire SE, Desfire EV1, NFC
 4. Reader to come pre-paired with an Aperio hub and communicate with the hub via IEEE802.14.4 (2.4 GHz) wireless technology.
 5. Aperio hub to communicate with the access control panel using industry standard Wiegand protocol interface.
 6. Reader to have green LED status indicator.
 7. Reader type and model to meet the design and mounting applications needs of each entry point as indicated on the drawings.
 8. Manufacturers:
 - a. Securitron (SU) - R100 Series.
- D. Door Position Switches: Door position magnetic reed contact switches specifically designed for use in commercial door applications. On recessed models the contact and magnetic housing snap-lock into a 1" diameter hole. Surface mounted models include wide gap distance design complete

with armored flex cabling. Provide SPDT, N/O switches with optional Rare Earth Magnet installation on steel doors with flush top channels.

1. Manufacturers:

- a. Alarm Controls (AK) - CP1-1026 Series.
- b. Securitron (SU) - DPS Series.

E. Intelligent Switching Power Supplies: Provide the least number of power supplies at the appropriate amperage level sufficient to exceed the required total draw for the specified electrified hardware and access control equipment.

1. Power supplies shall meet all functions and features as specified herein.

- a. UL listed dual voltage 12 or 24 VDC field selectable continuous output.
- b. Dedicated fast charger to prolong battery life with low battery cutoff to protect batteries from deep discharge.
- c. Enhanced surge immunity for input/output protection
- d. Separate, dedicated battery charging circuit to keep locks cooler.
- e. Dual-color LED visual notification to prevent applying incorrect voltages to the power supply.
- f. Instant auto-switch to battery on AC loss.
- g. Expandable up to 16 outputs in the standard enclosure
- h. Integrated fire alarm interface to allow main output shutdown or disconnect on a per output basis when using an R8 output module.
- i. Network ready and remotely manage locks and connected devices when using an M8 managed output module on network models.
- j. Lifetime replacement, no-fault, no questions asked warranty.

2. Manufacturers:

- a. Securitron (SU) - AQL Series.

2.16 FABRICATION

- A. Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to manufacturers recognized installation standards for application intended.

2.17 FINISHES

- A. Standard: Designations used in the Hardware Sets and elsewhere indicate hardware finishes complying with ANSI/BHMA A156.18, including coordination with traditional U.S. finishes indicated by certain manufacturers for their products.
- B. Provide quality of finish, including thickness of plating or coating (if any), composition, hardness, and other qualities complying with manufacturer's standards, but in no case less than specified by referenced standards for the applicable units of hardware

- C. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine scheduled openings, with Installer present, for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Notify architect of any discrepancies or conflicts between the door schedule, door types, drawings and scheduled hardware. Proceed only after such discrepancies or conflicts have been resolved in writing.

3.2 PREPARATION

- A. Hollow Metal Doors and Frames: Comply with ANSI/DHI A115 series.
- B. Wood Doors: Comply with ANSI/DHI A115-W series.

3.3 INSTALLATION

- A. Install each item of mechanical and electromechanical hardware and access control equipment to comply with manufacturer's written instructions and according to specifications.
 - 1. Installers are to be trained and certified by the manufacturer on the proper installation and adjustment of fire, life safety, and security products including: hanging devices; locking devices; closing devices; and seals.
- B. Paint prime coated mullions to match frames.
- C. Mounting Heights: Mount door hardware units at heights indicated in following applicable publications, unless specifically indicated or required to comply with governing regulations:
 - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
 - 2. DHI TDH-007-20: Installation Guide for Doors and Hardware.
 - 3. Where indicated to comply with accessibility requirements, comply with ANSI A117.1 "Accessibility Guidelines for Buildings and Facilities."
 - 4. Provide blocking in drywall partitions where wall stops or other wall mounted hardware is located.
- D. Retrofitting: Install door hardware to comply with manufacturer's published templates and written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and

reinstallation of surface protective trim units with finishing work specified in Division 9 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.

- E. Push Plates and Door Pulls: When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.
- F. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- G. Storage: Provide a secure lock up for hardware delivered to the project but not yet installed. Control the handling and installation of hardware items so that the completion of the work will not be delayed by hardware losses before and after installation.

3.4 FIELD QUALITY CONTROL

- A. Field Inspection (Punch Report): Reference Division 01 Sections "Closeout Procedures". Produce project punch report for each installed door opening indicating compliance with approved submittals and verification hardware is properly installed, operating and adjusted. Include list of items to be completed and corrected, indicating the reasons or deficiencies causing the Work to be incomplete or rejected.
 - 1. Organization of List: Include separate Door Opening and Deficiencies and Corrective Action Lists organized by Mark, Opening Remarks and Comments, and related Opening Images and Video Recordings.

3.5 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

3.6 CLEANING AND PROTECTION

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by door hardware installation.
- C. Clean operating items as necessary to restore proper finish. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of owner occupancy.

3.7 DEMONSTRATION

- A. Instruct Owner's maintenance personnel to adjust, operate, and maintain mechanical and electromechanical door hardware.

3.8 DOOR HARDWARE SETS

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

- 1. Quantities listed are for each pair of doors, or for each single door.
- 2. The supplier is responsible for handing and sizing all products.
- 3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.
- 4. At existing openings with new hardware the supplier shall field inspect existing conditions prior to the submittal stage to verify the specified hardware will work as required. Provide alternate solutions and proposals as needed.

- B. Manufacturer's Abbreviations:

- 1. MK - McKinney
- 2. PE - Pemko
- 3. MR - Markar
- 4. SU - Securitron
- 5. RO - Rockwood
- 6. SA - SARGENT
- 7. NO - Norton Rixson
- 8. OT - Other

Hardware Sets

Set: 1.0

Doors: 101, 114

Description: Exterior Aluminum Nightlatch Exit Pair w/ Closer, Card Reader, Remote Release

2 Continuous Hinge	CFM__SLF-HD1 PT - DOOR HEIGHT	PE	087100	
2 Electric Power Transfer	EL-CEPT	630	SU	087100 ⚡
1 Removable Mullion	L980A - DOOR HEIGHT	US28	SA	087100
1 Rim Exit Device, Dummy	16 55 PE8810 PTB	US32D	SA	087100 ⚡
1 Rim Exit Device, Storeroom	16 55 56 PE8804 PSB	US32D	SA	087100 ⚡
1 Cylinder	22 980C1	US26D	SA	087100
2 Surface Closer	281 CPS	EN	SA	087100
2 Astragal	18061CNB		PE	087100
1 Rain Guard	346C		PE	087100
1 Gasketing	303AV TKSP		PE	087100
1 Gasketing (Mullion)	5110BL		PE	087100
2 Sweep (w/ drip edge)	3452CNB		PE	087100
1 Threshold	252x3AFG MSES25SS		PE	087100
2 Frame Harness	QC-C1500P		MK	087100 ⚡
2 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100 ⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500 ⚡
2 Door Position Switch	DPS-M/W-BK (TO SUIT)		SU	087100 ⚡
1 Power Supply	AQL4-R8E1		SU	087100 ⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100 ⚡

Notes: Doors normally closed and locked

Entry by card reader, key or when in a timed unlock by access control system programming, or remote release

Free egress at all times

Set: 2.0

Doors: 112, 115.2

Description: Exterior Aluminum Nightlatch Exit w/ Closer, Card Reader, Remote Release

1 Continuous Hinge	CFM__SLF-HD1 PT - DOOR HEIGHT	PE	087100	
1 Electric Power Transfer	EL-CEPT	630	SU	087100 ⚡
1 Rim Exit Device, Storeroom	16 55 56 PE8804 PSB	US32D	SA	087100 ⚡
1 Surface Closer	281 CPS	EN	SA	087100
1 Rain Guard	346C		PE	087100
1 Gasketing	303AV TKSP		PE	087100
1 Sweep (w/ drip edge)	3452CNB		PE	087100
1 Threshold	252x3AFG MSES25SS		PE	087100
1 Frame Harness	QC-C1500P		MK	087100 ⚡
1 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100 ⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500 ⚡
1 Door Position Switch	DPS-M/W-BK (TO SUIT)		SU	087100 ⚡
1 Power Supply	AQL4-R8E1		SU	087100 ⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100 ⚡

Notes: Door normally closed and locked
 Entry by card reader or key
 Free egress at all times

Set: 3.0

Doors: 109

Description: Storeroom Pair

2 Continuous Hinge	CFM__SLF-HD1 - DOOR HEIGHT	PE	087100	
1 Flush Bolt	2845	US32D	RO	087100
1 Dust Proof Strike	570	US26D	RO	087100
1 Closet/Storeroom Lock	22 8227 LNL	US26D	SA	087100
1 Coordinator	1700	US28	RO	087100
2 Surface Closer	281 CPSH	EN	SA	087100
2 Astragal	18061CNB		PE	087100
1 Gasketing	303AV TKSP		PE	087100

Set: 4.0

Doors: 111

Description: Exterior Storage

1 Continuous Hinge	CFM__SLF-HD1 - DOOR HEIGHT	PE	087100	
1 Closet/Storeroom Lock	22 8227 LNL	US26D	SA	087100
1 Surface Closer	281 CPSH	EN	SA	087100
1 Rain Guard	346C		PE	087100
1 Gasketing	303AV TKSP		PE	087100
1 Sweep (w/ drip edge)	3452CNB		PE	087100
1 Threshold	252x3AFG MSES25SS		PE	087100

Set: 5.0

Doors: [127](#)

Description: Vault

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100	
1 Electric Power Transfer	EL-CEPT	630	SU	087100	⚡
1 Electrified Mortise Lock	22 IDP NAC-82271-24v LNL	US26D	SA	087100	⚡
1 Surface Closer	281 P10	EN	SA	087100	
1 Kick Plate	K1050 10" CSK	US32D	RO	087100	
1 Wall Stop	409	US32D	RO	087100	
1 Gasketing (Head/Jambs)	S88BL		PE	087100	
1 Frame Harness	QC-C1500P		MK	087100	⚡
1 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100	⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500	⚡
1 Power Supply	AQL4-R8E1		SU	087100	⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100	⚡

Notes: Door normally closed and locked
 Entry by card reader or key
 Free egress at all times

Lockset has integrated request to exit and door position switches

Set: 6.0

Doors: [123](#), [124](#)

Description: Records, Evidence

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100	
1 Electric Power Transfer	EL-CEPT	630	SU	087100	⚡
1 Electrified Mortise Lock	22 IDP NAC-82271-24v LNL	US26D	SA	087100	⚡
1 Surface Closer	281 OTB	EN	SA	087100	
1 Kick Plate	K1050 10" CSK	US32D	RO	087100	
1 Wall Stop	409	US32D	RO	087100	
1 Gasketing (Head/Jambs)	S88BL		PE	087100	
1 Frame Harness	QC-C1500P		MK	087100	⚡
1 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100	⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500	⚡
1 Power Supply	AQL4-R8E1		SU	087100	⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100	⚡

Notes: Door normally closed and locked
 Entry by card reader or key
 Free egress at all times

Lockset has integrated request to exit and door position switches

Set: 7.0

Doors: [102](#), [104](#), [105](#), [125](#), [126](#)

Description: Privacy

3 Hinge, Full Mortise	TA2714	US26D	MK	087100
1 Privacy Lock	LB V21 8266 LNL	US26D	SA	087100
1 Surface Closer	281 OTB	EN	SA	087100
1 Kick Plate	K1050 10" CSK	US32D	RO	087100
1 Mop Plate	K1050 4" CSK	US32D	RO	087100
1 Wall Stop	409	US32D	RO	087100
1 Coat Hook	RM802	US32D	RO	087100

Set: 8.0

Doors: [103](#)

Description: Vestibule

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100	
1 Electric Power Transfer	EL-CEPT	630	SU	087100	⚡
1 Electrified Mortise Lock	22 IDP NAC-82271-24v LNL	US32D	SA	087100	⚡
1 Surface Closer	281 P10	EN	SA	087100	
1 Wall Stop	409	US32D	RO	087100	
1 Frame Harness	QC-C1500P		MK	087100	⚡
1 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100	⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500	⚡
1 Door Position Switch	DPS-M/W-BK (TO SUIT)		SU	087100	⚡
1 Power Supply	AQL4-R8E1		SU	087100	⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100	⚡

Notes: Door normally closed and locked

Entry by card reader or key

Free egress at all times

Set: 9.0

Doors: [112.1](#)

Description: Training Room

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100
1 Storeroom/Closet Lock	22 8204 LNL	US32D	SA	087100
1 Surface Closer	281 P10	EN	SA	087100
1 Kick Plate	K1050 10" CSK	US32D	RO	087100
1 Wall Stop	409	US32D	RO	087100

Set: 10.0

Doors: [108](#)

Description: Training Room

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100
1 Storeroom/Closet Lock	22 8204 LNL	US32D	SA	087100
1 Surface Closer	281 P10	EN	SA	087100
1 Wall Stop	409	US32D	RO	087100

Set: 11.0

Doors: [106](#), [107](#), [110](#), [113](#)

Description: Storeroom w/ Closer

3 Hinge, Full Mortise	TA2714	US26D	MK	087100
1 Storeroom/Closet Lock	22 8204 LNL	US26D	SA	087100
1 Surface Closer	281 OTB	EN	SA	087100
1 Wall Stop	409	US32D	RO	087100
3 Silencer	608-RKW		RO	087100

Set: 11.1

Doors: [130.1](#)

Description: Storeroom w/ Closer

3 Hinge, Full Mortise	TA2714	US26D	MK	087100
1 Storeroom/Closet Lock	22 8204 LNL	US26D	SA	087100
1 Surface Closer	281 CPS	EN	SA	087100
1 Wall Stop	409	US32D	RO	087100
3 Silencer	608-RKW		RO	087100

Set: 12.0

Doors: [117](#), [118](#), [119](#), [121](#), [122](#), [128](#), [129](#), [130](#)

Description: Office

3 Hinge, Full Mortise	TA2714	US26D	MK	087100
1 Office/Entry Lock	22 8205 LNL	US26D	SA	087100
1 Wall Stop	409	US32D	RO	087100
3 Silencer	608-RKW		RO	087100
1 Coat Hook	RM802	US32D	RO	087100

Set: 13.0

Doors: [120](#)

Description: Conference

3 Hinge, Full Mortise	TA2714	US26D	MK	087100
1 Passage Latch	8215 LNL	US26D	SA	087100
1 Wall Stop	409	US32D	RO	087100
3 Silencer	608-RKW		RO	087100

Set: 14.0

Doors: [114.1](#), [115](#)

Description: Classroom (passage or storeroom) w/ Closer

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100
1 Classroom Lock	22 8237 LNL	US26D	SA	087100
1 Surface Closer	281 P10	EN	SA	087100
1 Wall Stop	409	US32D	RO	087100

Notes:

Set: 15.0

Doors: [116](#)

Description: Classroom w/ Closer

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100
1 Classroom Lock	22 8237 LNL	US26D	SA	087100
1 Surface Closer	281 OTB	EN	SA	087100
1 Wall Stop	409	US32D	RO	087100

Notes:

Set: 16.0

Doors: [115.1](#)

Description: Lockset w/ Closer, Card Reader, Remote Release

3 Hinge (heavy weight)	T4A3786	US26D	MK	087100	
1 Electric Power Transfer	EL-CEPT	630	SU	087100	⚡
1 Electrified Mortise Lock	22 IDP NAC-82271-24v LNL	US26D	SA	087100	⚡
1 Surface Closer	281 CPS	EN	SA	087100	
1 Frame Harness	QC-C1500P		MK	087100	⚡
1 Door Harness	QC-CXXX- LENGTH TO SUIT		MK	087100	⚡
1 Card Reader	BY SECURITY SUPPLIER		OT	281500	⚡
1 Power Supply	AQL4-R8E1		SU	087100	⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		SA	087100	⚡

Notes: Door normally closed and locked
 Entry by card reader, key or remote release
 Free egress at all times

Lockset has integrated request to exit and door position switches

END OF SECTION 087100

THIS PAGE INTENTIONALLY LEFT BLANK