

# *Homer Lewis & Associates, Inc.*

## *Architecture*

**New Phoenix**

**Job Number 2515**

**Date: March 26, 2026**

**Addendum Number 01**

1. Drawings: Sheet M-1, "All exposed duct..." note below north arrow: Delete original note in its entirety and substitute the following:
  - a. All the exposed ducts shall be insulated with a 1" liner and painted.
  - b. Alternate: Equivalent spiral ducts.
2. Drawings: Sheet P-3, Plumbing Fixture Schedule, "EWH-Electric Water Heaters", Fixture note changed to:
  - a. Fixture Rheem ES50-27-G, 27KW, 208/3/60 Volts, 124 GPH Heat Recovery at 90 Degree F Rise.
3. Flooring is N.I.C. by owner's vendor.
4. See attached Proposal Form.
5. Kitchen equipment, walk-in cooler/freezer and Furnishings are N.I.C. by Owner.
6. Current site work is limited to that which affects the building and new additions. Additional paving and parking lot improvements to be determined at a later date.
7. To access the existing building, call Brett Riccardi at 678-851-0332.