

## SECTION 102113.17 - PHENOLIC TOILET COMPARTMENTS

### PART 1 GENERAL

#### 1.1 SECTION INCLUDES

- A. Phenolic toilet compartments.
- B. Urinal screens.

#### 1.2 RELATED REQUIREMENTS

- A. Section 061001 - Rough Carpentry - Architecture: Blocking and supports.
- B. Section 102800 - Toilet, Bath, and Laundry Accessories.

#### 1.3 REFERENCE STANDARDS

- A. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.

#### 1.4 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate the work with placement of support framing and anchors in walls and ceilings.

#### 1.5 SUBMITTALS

- A. See Section 013300 - Submittal Procedures for submittal procedures.
- B. Product Data: Provide data on panel construction, hardware, and accessories.
- C. Shop Drawings: Indicate partition plan, elevation views, dimensions, details of wall supports, door swings.
- D. Samples: Submit two samples of partition panels, 2 by 3 inch in size illustrating panel finish, color, and sheen.
- E. Manufacturer's Installation Instructions: Indicate special procedures.

### PART 2 PRODUCTS

#### 2.1 MANUFACTURERS

- A. Phenolic Toilet Compartments:
  - 1. Basis of Design: ASI Accurate Partitions; Maximum Privacy Phenolic: [www.asi-accuratepartitions.com/#sle](http://www.asi-accuratepartitions.com/#sle).
  - 2. Substitutions: Section 016000 - Product Requirements.

## 2.2 PHENOLIC TOILET COMPARTMENTS

- A. Toilet Compartments: Factory fabricated doors, pilasters, and divider panels made of solid phenolic core panels with integral melamine finish, floor-to-ceiling.
  - 1. Color: Single color as selected.
- B. Doors:
  - 1. Thickness: 3/4 inch.
  - 2. Width: 24 inch.
  - 3. Width for Handicapped Use: 36 inch, door swing as indicated on the plans.
  - 4. Height: 118 inch.
  - 5. "No Sight" configuration.
- C. Panels:
  - 1. Thickness: 3/4 inch.
  - 2. Height: 120 inch.
  - 3. Depth: As indicated on drawings.
- D. Pilasters:
  - 1. Thickness: 3/4 inch.
  - 2. Width: As required to fit space; minimum 3 inch.
- E. Screens: Without doors; to match compartments; mounted to wall with two panel brackets with vertical support/bracing same as compartments.

## 2.3 ACCESSORIES

- A. Pilaster Shoes: Formed ASTM A666 Type 304 stainless steel with No. 4 finish, 3 inch high, concealing floor fastenings.
  - 1. Provide adjustment for floor variations with screw jack through steel saddles integral with pilaster.
  - 2. Provide ceiling attachment using two adjustable hanging studs, attached to above-ceiling framing.
- B. Wall and Pilaster Brackets: Anodized aluminum, black color; continuous type.
- C. Attachments, Screws, and Bolts: Stainless steel, tamper proof type.
- D. Hardware: Black anodized aluminum:
  - 1. Pivot hinges, gravity type, adjustable for door close positioning; two per door.
  - 2. Door Latch: Slide type with exterior emergency access feature.
  - 3. Door strike and keeper with rubber bumper; mounted on pilaster in alignment with door latch.
  - 4. Coat hook with rubber bumper; one per compartment, mounted on door.
  - 5. Provide door pull for outswinging doors.

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Verify that field measurements are as indicated.

- B. Verify correct spacing of and between plumbing fixtures.
- C. Verify correct location of built-in framing, anchorage, and bracing.

### 3.2 INSTALLATION

- A. Install partitions secure, rigid, plumb, and level in accordance with manufacturer's instructions.
- B. Maintain 3/8 inch to 1/2 inch space between wall and panels and between wall and end pilasters.
- C. Attach panel brackets securely to walls using anchor devices.
- D. Attach panels and pilasters to brackets.
- E. Field touch-up of scratches or damaged finish will not be permitted. Replace damaged or scratched materials with new materials.

### 3.3 TOLERANCES

- A. Maximum Variation From True Position: 1/4 inch.
- B. Maximum Variation From Plumb: 1/8 inch.

### 3.4 ADJUSTING

- A. Adjust hinges to position doors in partial opening position when unlatched. Return out-swinging doors to closed position.
- B. Adjust adjacent components for consistency of line or plane.

END OF SECTION 102113.17