



BROWN AND CALDWELL
900 HAMMOND DRIVE, SUITE 500
ATLANTA, GA 30328



THIS DRAWING IS NOT VALID
FOR CONSTRUCTION
PURPOSES UNLESS IT BEARS
THE SEAL AND SIGNATURE OF
A DULY REGISTERED
PROFESSIONAL



CONSTRUCTION
DOCUMENTS
07/01/2026



NCWSA OFFICE
ADDITION

REVISIONS

[illegible]

LINE IS 2 INCHES
AT FULL SIZE

DESIGNED: MAF

DRAWN: MAF

CHECKED: JFW

CHECKED:

APPROVED:

FILENAME

BC PROJECT NUMBER

6202

CLIENT PROJECT NUMBER

ELECTRICAL
COMCHECK

DRAWING NUMBER

E004

A	B	C	D
Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	# of Fixture	Fixture Watt.	(B X C)
T42: T42: LED:	1	40	40
15-Copy 246 (Common Space Types:Copy/Print Room)			
TH42: TH42: LED:	1	55	55
16-Office 245 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
17-Office 248 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
18-Strg 249 (Common Space Types:Storage >=50 - <=1000 sq.ft.)			
SW4: SW4: LED:	1	37	37
19-Office 253 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
20-Office 263 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
21-Closet 259 (Common Space Types:Storage <50 sq.ft.)			
T22: T22: LED:	1	16	16
22-Office 258 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
23-Office 267 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
24-Office 256 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
25-Office 255 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
26-Office 262 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
27-Office 251 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
28-Office 247 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
29-Office 191 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
30-Office 243 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
31-Office 240 (Common Space Types:Office - Enclosed)			
TH42: TH42: LED:	1	55	55
32-Conf 237 (Common Space Types:Conference/Meeting/Multiurpose)			
T42: T42: LED:	4	40	160

Total Proposed Watts:

Proposed Interior Lighting Controls

Fixture	Lighting Control
1:Vestibule 100 (Common Space Types:Corridor/Transition >=8 ft wide)	
A6: A6: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
2:Lobby 101 (Common Space Types:Lobby - General)	
A6: A6: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control

Fixture	Lighting Control
EX: EX: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>3-Men 145 (Common Space Types:Restrooms)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>4-Women 146 (Common Space Types:Restrooms)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>5-Prefunction 144 (Common Space Types:Lobby - General)</u>	
A6: A6: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
EX: EX: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>6-Bard Room 143 (Common Space Types:Classroom/Lecture/Training)</u>	
A6: A6: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>7-Executive Conf 140 (Common Space Types:Conference/Meeting/Multiurpose)</u>	
A6: A6: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
P8: P8: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>8-Storage 142 (Common Space Types:Storage >=50 - <=1000 sq ft)</u>	
SW4: SW4: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>9-Elec Room 141 (Common Space Types:Electrical/Mechanical)</u>	
SW4: SW4: LED:	Occupancy Sensor, Manual Control
<u>10-Corridor 260 (Common Space Types:Corridor/Transition >=8 ft wide)</u>	
T22: T22: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>11-Conf 238 (Common Space Types:Conference/Meeting/Multiurpose)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>12-Office 239 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>13-Restrm 241 (Common Space Types:Restrooms)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>14-Restrm 242 (Common Space Types:Restrooms)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>15-Copy 246 (Common Space Types:Copy/Print Room)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch
<u>16-Office 245 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>17-Office 248 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>18-Str 249 (Common Space Types:Storage >=50 - <=1000 sq ft)</u>	
SW4: SW4: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>19-Office 253 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>20-Office 243 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>21-Closed 259 (Common Space Types:Storage <=50 sq ft)</u>	
T22: T22: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>22-Office 258 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>23-Office 267 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>24-Office 256 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control

Fixture	Lighting Control
<u>25-Office 255 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>26-Office 252 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>27-Office 251 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>28-Office 247 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>29-Office 101 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>30-Office 243 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>31-Office 240 (Common Space Types:Office - Enclosed)</u>	
TH42: TH42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control
<u>32-Conf 237 (Common Space Types:Conference/Meeting/Multimedia)</u>	
T42: T42: LED:	Occupancy Sensor, Interior Timeswitch, Manual Control

Interior Lighting PASSES: Design 51% better than code

Interior Lighting Compliance Statement

Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2015 IECC requirements in COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Name - Title	Signature	Date
Matt Potts - Electrical Designer	Matt Potts	08/18/2026