DISTRIBUTION PANEL SCHEDULE

PANELBOARD **MDP** | NAME | VOLTS: **208 Y/120** | 3Ø 4-WIRE | BUS CAPACITY: **1200** A | AIC: **42kA** | MCB: **1200** A | MTG: **SURFACE** | MLO: | ENCL: **NEMA 1** | MECH/ELEC RM 141 | LOCATION

No.	BKR	DESCRIPTION	TYPE	LOAD	L1	L2	L3	LOAD	TYPE	DESCRIPTION	BKR	No.
1					0							2
3						0						4
5							0					6
7					0							8
9						0						10
11							0					12
13					0							14
15						0						16
17							0					18
19			HVAC	7446	15613			8167	HVAC			20
21	80A/3P	ROOF TOP UNIT - RTU-1	HVAC	7446		15613		8167	HVAC	ROOF TOP UNIT - RTU-3	90A/3P	22
23			HVAC	7446			15613	8167	HVAC			24
25			HVAC	7446	26286			18840	PWR			26
27	80A/3P	ROOF TOP UNIT - RTU-2	HVAC	7446		26190		18744	PWR	PANELBOARD - PP1	200A/3P	28
29			HVAC	7446			23674	16228	PWR			30
31			PWR	10376	14836			4460	PWR			32
33	100A/3P	PANELBOARD - PP2	PWR	8940		13760		4820	PWR	PANELBOARD - PP3	100A/3P	34
35			PWR	9351			13311	3960	PWR			36
37			PWR		0				PWR			38
39	200A/3P	PANELBOARD - L2	PWR			0			PWR	PANELBOARD - MPL	175A/3P	40
41			PWR				0		PWR			42

PANELBOARD SCHEDULE

PANELBOARD **PP1** | NAME | VOLTS: **208 Y/120** | 3Ø 4-WIRE | BUS CAPACITY: **200** A | AIC: **42kA** | MCB: | MTG: **SURFACE** | MLO: **200** A | ENCL: **NEMA 1** | MECH/ELEC RM 141 | LOCATION

No.	BKR	DESCRIPTION	TYPE	LOAD	L1	L2	L3	LOAD	TYPE	DESCRIPTION	BKR	No.
1			HVAC	1670	2739			1069	HVAC			2
3	20A/3P	VAV1-1	HVAC	1670		2739		1069	HVAC	VAV2-4	20A/3P	4
5			HVAC	1670			2739	1069	HVAC			6
7			HVAC	2030	2859			829	HVAC			8
9	30A/3P	VAV1-2	HVAC	2030		2859		829	HVAC	VAV2-5	20A/3P	10
11			HVAC	2030			2859	829	HVAC			12
13			HVAC	937	2835			1898	HVAC			14
15	20A/3P	VAV1-3	HVAC	937		2835		1898	HVAC	VAV3-1	20A/3P	16
17			HVAC	937			2835	1898	HVAC			18
19			HVAC	1033	2306			1273	HVAC			20
21	20A/3P	VAV1-4	HVAC	1033		2306		1273	HVAC	VAV3-2	20A/3P	22
23			HVAC	1033			2306	1273	HVAC			24
25			HVAC	1273	2474			1201	HVAC			26
27	20A/3P	VAV2-1	HVAC	1273		2474		1201	HVAC	VAV3-3	20A/3P	28
29			HVAC	1273			2474	1201	HVAC			30
31			HVAC	1466	4462			2996	PWR			32
33	20A/3P	VAV2-2	HVAC	1466		4462		2996	PWR	EWH-1	40A/2P	34
35			HVAC	1466			1946	480	HVAC	EF-1	15A/1P	36
37			HVAC	1069	1165			96	PWR	HWRP-1	15A/1P	38
39	20A/3P	VAV2-3	HVAC	1069		1069				SPARE	20A/1P	40
41			HVAC	1069			1069			SPARE	20A/1P	42

PANELBOARD SCHEDULE

PANELBOARD **PP2** | NAME | VOLTS: **208 Y/120** | 3Ø 4-WIRE | BUS CAPACITY: **100** A | AIC: **42kA** | MCB: | MTG: **SURFACE** | MLO: **100** A | ENCL: **NEMA 1** | MECH/ELEC RM 141 | LOCATION

No.	BKR	DESCRIPTION	TYPE	LOAD	L1	L2	L3	LOAD	TYPE	DESCRIPTION	BKR	No.
1	20A/1P	LIGHTING - ROOM 100, 101, 102	LTG	570	1290			720	REC	RECEPTACALES - ROOM 142	20A/1P	2
3	20A/1P	LIGHTING - ROOM 105, 115	LTG	160		880		720	REC	RECEPTACALES - ROOM 140	20A/1P	4
5	20A/1P	LIGHTING - ROOM 144, 145, 146	LTG	442			1162	720	REC	RECEPTACALES - ROOM 140	20A/1P	6
7	20A/1P	LIGHTING - ROOM 143	LTG	891	1611			720	REC	RECEPTACALES - ROOM 139	20A/1P	8
9	20A/1P	LIGHTING - ROOM 112,139,140,141,142	LTG	720		1260		540	REC	RECEPTACALES - ROOM 139	20A/1P	10
11	20A/1P	LIGHTING - ROOM 259, 260, 261, 262	LTG	389			1389	1000	REC	REC - ROOM 139 (FRIDGE GCFI BKR)	20A/1P	12
13	20A/1P	LIGHTING - ROOM 237-249, 252-58	LTG	1288	2368			1080	REC	RECEPTACLES - ROOM 222, 229, 235	20A/1P	14
15	20A/1P	RECEPTACALES - ROOM 100, 101	REC	720		1800		1080	REC	RECEPTACLES - ROOM 237	20A/1P	16
17	20A/1P	RECEPTACALES - ROOM 102	REC	720			1800	1080	REC	RECEPTACLES - ROOM 238	20A/1P	18
19	20A/1P	RECEPTACALES - ROOM 105	REC	720	1620			900	REC	RECEPTACLES - ROOM 239	20A/1P	20
21	20A/1P	RECEPTACALES - ROOM 115	REC	540		1440		900	REC	RECEPTACLES - ROOM 240	20A/1P	22
23	20A/1P	RECEPTACALES - ROOM 144	REC	720			1440	720	REC	RECEPTACLES - ROOM 241,242	20A/1P	24
25	20A/1P	RECEPTACALES - ROOM 145	REC	540	1440			900	REC	RECEPTACLES - ROOM 243	20A/1P	26
27	20A/1P	RECEPTACALES - ROOM 146	REC	540		1440		900	REC	RECEPTACLES - ROOM 244	20A/1P	28
29	20A/1P	RECEPTACALES - ROOM 143	REC	900			1800	900	REC	RECEPTACLES - ROOM 247	20A/1P	30
31	20A/1P	RECEPTACALES - ROOM 143	REC	900	1400			500	PWR	UR-1, UR-1, WC-1, WC-1, WC-1, WC-1	20A/1P	32
33	20A/1P	RECEPTACALES - ROOM 143	REC	720		1220		500	PWR	WC-1, WC-1	20A/1P	34
35	20A/1P	RECEPTACALES - ROOM 143	REC	720			1220	500	PWR	WC-1, WC-1	20A/1P	36
37	20A/1P	RECEPTACALES - ROOM 112	REC	900	900					SPARE	20A/1P	38
39	20A/1P	RECEPTACALES - ROOM 110,111,138	REC	900		900				SPARE	20A/1P	40
41	20A/1P	RECEPTACALES - ROOM 142	REC	540			540			SPARE	20A/1P	42

PANELBOARD SCHEDULE

PANELBOARD **PP3** | NAME | VOLTS: **208 Y/120** | 3Ø 4-WIRE | BUS CAPACITY: **100** A | AIC: **42kA** | MCB: | MTG: **SURFACE** | MLO: **100** A | ENCL: **NEMA 1** | ELEC ROOM 141 | LOCATION

No.	BKR	DESCRIPTION	TYPE	LOAD	L1	L2	L3	LOAD	TYPE	DESCRIPTION	BKR	No.
1	20A/1P	RECEPTACLES - ROOM 251	REC	900	900					SPARE	20A/1P	2
3	20A/1P	RECEPTACLES - ROOM 252	REC	900		900				SPARE	20A/1P	4
5	20A/1P	RECEPTACLES - ROOM 255	REC	900			900			SPARE	20A/1P	6
7	20A/1P	RECEPTACLES - ROOM 256	REC	900	900					SPARE	20A/1P	8
9	20A/1P	RECEPTACLES - ROOM 257	REC	900		900				SPARE	20A/1P	10
11	20A/1P	RECEPTACLES - ROOM 258	REC	900			900			SPARE	20A/1P	12
13	20A/1P	RECEPTACLES - ROOM 254	REC	900	900					SPARE	20A/1P	14
15	20A/1P	RECEPTACLES - ROOM 253	REC	900		900				SPARE	20A/1P	16
17	20A/1P	RECEPTACLES - ROOM 248	REC	900			900			SPARE	20A/1P	18
19	20A/1P	RECEPTACLES - ROOM 249	REC	540	540					SPARE	20A/1P	20
21	20A/1P	RECEPTACLES - ROOM 245	REC	900		900				SPARE	20A/1P	22
23	20A/1P	RECEPTACLES - ROOM 246	REC	720			720			SPARE	20A/1P	24
25	20A/1P	RECEPTACLES - ROOM 259, 260, 261	REC	720	720					SPARE	20A/1P	26
27	20A/1P	RECEPTACLES - ROOM 261, 262	REC	720		720				SPARE	20A/1P	28
29	20A/1P	RECEPTACLES - ROOF	REC	540			540			SPARE	20A/1P	30
31	20A/1P	RECEPTACLES - ROOM 142 (A/V RACK)	REC	500	500					SPARE	20A/1P	32
33	20A/1P	RECEPTACLES - ROOM 249 (NETW. RACK)	REC	500		500				SPARE	20A/1P	34
35	20A/1P	SPARE					0			SPARE	20A/1P	36
37	20A/1P	SPARE			0					SPARE	20A/1P	38
39	20A/1P	SPARE				0				SPARE	20A/1P	40
41	20A/1P	SPARE					0			SPARE	20A/1P	42

Brown AND Caldwell
BROWN AND CALDWELL
900 HAMMOND DRIVE, SUITE 500
ATLANTA, GA 30328

wendel

THIS DRAWING IS NOT VALID FOR CONSTRUCTION PURPOSES UNLESS IT BEARS THE SEAL AND SIGNATURE OF A DULY REGISTERED PROFESSIONAL

GEORGIA REGISTERED No. PE046069 PROFESSIONAL ENGINEER JESSE F. WENDELL
06/20/2026

CONSTRUCTION DOCUMENTS
07/01/2026

NCWSA NEWTON COUNTY WATER & SEWERAGE AUTHORITY

NCWSA OFFICE ADDITION

REVISIONS

REV	DATE	DESCRIPTION

LINE IS 2 INCHES AT FULL SIZE

DESIGNED: MAP
DRAWN: MAP
CHECKED: JFW
CHECKED:
APPROVED:
FILENAME
BC PROJECT NUMBER 616202
CLIENT PROJECT NUMBER

ELECTRICAL

PANELBOARD SCHEDULES

DRAWING NUMBER
E504