

SECTION 077200 - ROOF ACCESSORIES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Roof curbs.
- B. Equipment rails.
- C. Roof penetrations mounting curbs.
- D. Rooftop mounted guardrails.
- E. Roof hatches.
- F. Non-penetrating pedestals.

1.2 RELATED REQUIREMENTS

- A. Section 077100 - Roof Specialties: Other manufactured roof specialty items.

1.3 REFERENCE STANDARDS

- A. 29 CFR 1910.23 - Ladders.
- B. 29 CFR 1910.29 - Fall Protection Systems and Falling Object Protection - Criteria and Practices.
- C. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- D. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
- E. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- F. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- G. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation.

1.4 SUBMITTALS

- A. See Section 013300 - Submittal Procedures for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used.
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.

3. Installation methods.
 4. Maintenance requirements.
- C. Shop Drawings: Submit detailed layout developed for this project and provide dimensioned location and number for each type of roof accessory.
1. Non-penetrating Rooftop Supports: Submit design calculations for loadings and spacings.
- D. Warranty Documentation:
1. Submit manufacturer warranty.
 2. Ensure that forms have been completed in Owner's name and registered with manufacturer.
 3. Submit documentation that roof accessories are acceptable to roofing manufacturer, and do not limit the roofing warranty.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store products under cover and elevated above grade.

1.6 WARRANTY

- A. See Section 017700 - Closeout Procedures for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for all items in this Section. Complete forms in Owner's name and register with manufacturer.
- C. Extended Correction Period: Correct defective work within 5-year period commencing on Date of Substantial Completion.

PART 2 PRODUCTS

2.1 ROOF CURBS

- A. Roof Curbs Manufacturers:
 1. MKT Metal Manufacturing: www.mktduct.com/#sle.
 2. Substitutions: See Section 016000 - Product Requirements.
- B. Roof Curbs Mounting Assemblies: Factory fabricated hollow sheet metal construction, internally reinforced, and capable of supporting superimposed live and dead loads and designated equipment load with fully mitered and sealed corner joints welded or mechanically fastened, and integral counterflashing with top and edges formed to shed water.
 1. Roof Curb Mounting Substrate: Curb substrate consists of hollow-core concrete plank.
 2. Sheet Metal Material:
 - a. Aluminum: 0.080 inch minimum thickness, with 3003 alloy, and H14 temper.
 - 1) Finish: Mill finish.
 3. Roofing Cants: Provide integral sheet metal roofing cants dimensioned to begin slope at top of roofing system at 1:1 slope; minimum cant height 4 inches.

- C. Equipment Rail Curbs: Straight curbs on each side of equipment, with top of curbs horizontal and level with each other for equipment mounting.
 - 1. Provide preservative treated wood nailers along top of rails.
 - 2. Height Above Finished Roof Surface: 8 inches, minimum.
 - 3. Products:
 - a. MKT Metal Manufacturing: www.mktduct.com/#sle.
 - b. Substitutions: See Section 016000 - Product Requirements.
- D. Pipe, Duct, or Conduit Mounting Curbs: Vertical posts, minimum 8 inches square unless otherwise indicated.
 - 1. Provide sliding channel welded along top edge with adjustable height steel bracket, fabricated to fit item supported.
 - 2. Height Above Finished Roof Surface: 8 inches, minimum.

2.2 ROOF HATCHES AND VENTS

- A. Personnel Roof Hatch Manufacturers:
 - 1. Basis of Design: Bilco Company; Type S (ladder access) - stainless steel: www.bilco.com/#sle.
 - 2. Activar Construction Products Group, Inc. - JL Industries: www.activarcpg.com/#sle.
 - 3. Babcock-Davis: www.babcockdavis.com/#sle.
 - 4. Substitutions: See Section 016000 - Product Requirements.
- B. Frames and Curbs: One-piece curb and frame with integral cap flashing to receive roof flashings; extended bottom flange to suit mounting.
 - 1. Material: Mill finished aluminum, 11 gauge, 0.0907 inch thick.
 - 2. Insulation: Manufacturer's standard; 1 inch rigid glass fiber, located on outside face of curb.
 - 3. Curb Height: As indicated on drawings.
- C. Metal Covers: Flush, insulated, hollow metal construction.
 - 1. Capable of supporting 40 psf live load.
 - 2. Material: Mill finished aluminum; outer cover 11 gauge, 0.0907 inch thick, liner 0.04 inch thick.
 - 3. Insulation: Manufacturer's standard 1 inch rigid glass fiber.
 - 4. Gasket: Neoprene, continuous around cover perimeter.
- D. Hardware: Type 316 stainless steel, unless otherwise indicated or required by manufacturer.
 - 1. Lifting Mechanisms: Compression or torsion spring operator with shock absorbers that automatically opens upon release of latch; capable of lifting covers despite 10 psf load.
 - 2. Hinges: Heavy duty pintle type.
 - 3. Hold open arm with vinyl-coated handle for manual release.
 - 4. Latch: Upon closing, engage latch automatically and reset manual release.
 - 5. Manual Release: Pull handle on interior.
 - 6. Locking: Padlock hasp on interior.

2.3 NON-PENETRATING ROOFTOP SUPPORTS/ASSEMBLIES

- A. Non-Penetrating Rooftop Support/Assemblies: Manufacturer-engineered and factory-fabricated, with pedestal bases that rest on top of roofing membrane, and not requiring any attachment to roof structure and not penetrating roofing assembly.
 - 1. Design Loadings and Configurations: As required by applicable codes.
 - 2. Height: Provide minimum clearance of 8 inches under supported items to top of roofing.
 - 3. Support Spacing and Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
 - 4. Steel Components: Stainless steel in accordance with ASTM A123/A123M.
 - 5. Hardware, Bolts, Nuts, and Washers: Stainless steel in accordance with ASTM A153/A153M.
- B. Safety Railing System: Roof hatch safety rail system mounted directly to curb without penetration of roofing system.
 - 1. Railing Size: As indicated on drawings.
 - 2. Railing: Comply with 29 CFR 1910.23 for ladder safety, with safety factor of two.
 - 3. Self-Closing Gate: Comply with 29 CFR 1910.29 for safe egress and fall protection through hatch opening.
 - 4. Posts and Rails: Fiberglass-reinforced polymer tubing.
 - 5. Gate: Same material as railing; automatic closing with latch.
 - 6. Finish: Manufacturer's standard, factory-applied.
 - 7. Gate Hinges and Post Guides: ASTM B221 (ASTM B221M), 6063 alloy, T5 temper aluminum.
 - 8. Fasteners: Stainless steel, Type 316.
 - 9. Products:
 - a. Basis of Design: BILCO Company; Bil-Guard 2.0: www.bilco.com/#sle.
 - b. Substitutions: See Section 016000 - Product Requirements.
- C. Pipe Supports: Provide attachment fixtures complying with MSS SP-58 and as indicated.
- D. Non-Penetrating Pedestals: Steel pedestals with square, round, or rectangular bases.
 - 1. Bases: High density polypropylene.
 - 2. Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
 - 3. Steel Components: Stainless steel, or carbon steel hot-dip galvanized after fabrication in accordance with ASTM A123/A123M.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.

- B. Prepare surfaces using methods recommended by manufacturer for achieving acceptable results for applicable substrate under project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions, in manner that maintains roofing system weather-tight integrity.

3.4 CLEANING

- A. Clean installed work to like-new condition.

3.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.