

SECTION 104400 - FIRE PROTECTION SPECIALTIES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Fire extinguishers.
- B. Fire extinguisher cabinets.
- C. Accessories.

1.2 RELATED REQUIREMENTS

- A. Section 061001 - Rough Carpentry - Architecture: Wood blocking product and execution requirements.

1.3 REFERENCE STANDARDS

- A. NFPA 10 - Standard for Portable Fire Extinguishers.

1.4 SUBMITTALS

- A. See Section 013300 - Submittal Procedures for submittal procedures.
- B. Product Data: Provide extinguisher operational features and extinguisher ratings and classifications.
- C. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- D. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

1.5 FIELD CONDITIONS

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Fire Extinguishers:
 - 1. Basis of Design: Activar Construction Products Group, Inc. - JL Industries; Cosmic Extinguisher - Multipurpose Chemical: www.activarcpg.com.

2. Larsen's Manufacturing Co: www.larsensmfg.com.
3. Potter-Roemer: www.potterroemer.com.

B. Fire Extinguisher Cabinets and Accessories:

1. Basis of Design: Activar Construction Products Group, Inc. - JL Industries; Ambassador Series: www.activarcpg.com.
2. Larsen's Manufacturing Co: www.larsensmfg.com.
3. Potter-Roemer: www.potterroemer.com.
4. Substitutions: See Section 016000 - Product Requirements.

2.2 FIRE EXTINGUISHERS

- A. Fire Extinguishers - General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent.
- B. Multipurpose Dry Chemical Type Fire Extinguishers: Carbon steel tank, with pressure gauge.
1. Class: A:B:C type.
 2. Size: 10 pound.
 3. Finish: Baked polyester powder coat, red color.
 4. Temperature range: Minus 65 degrees F to 120 degrees F.

2.3 FIRE EXTINGUISHER CABINETS

- A. Utilize at locations marked "FEC"
- B. Cabinet Construction: Non-fire rated.
1. Formed powder-coated steel sheet; 0.036 inch thick base metal.
- C. Cabinet Configuration: Semi-recessed type.
1. Exterior nominal dimensions of 13-7/8 inch wide by 27-3/8 inch high by 6 inch deep.
 2. Projected Trim: Returned to wall surface, with 1-1/2 inch projection, and 1-1/4 inch wide face.
 3. Provide cabinet enclosure with right angle inside corners and seams, and with formed perimeter trim and door stiles.
- D. Door: 0.036 inch metal thickness, reinforced for flatness and rigidity with nylon catch and recessed handle. Hinge doors for 180 degree opening with continuous piano hinge.
- E. Door Glazing: Tempered glass, clear, 1/8 inch thick, and set in resilient channel glazing gasket.
- F. Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- G. Finish of Cabinet Exterior Trim and Door: Baked enamel, white color.
- H. Finish of Door Pull or Handle: Stainless steel.
- I. Finish of Cabinet Interior: White colored enamel.

2.4 ACCESSORIES

- A. Extinguisher Brackets: Formed steel, chrome-plated.

1. Utilize at locations marked "FE"
- B. Lettering: "FIRE EXTINGUISHER" decal, or vinyl self-adhering, prespaced black lettering in accordance with authorities having jurisdiction (AHJ).

PART 3 EXECUTION

3.1 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

3.2 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets plumb and level in wall openings, at height indicated on the drawings.
- C. Secure rigidly in place.
- D. Place extinguishers in cabinets.

3.3 MAINTENANCE

- A. See Section 017700 - Closeout Procedures for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for the service and maintenance of fire extinguishers for one years from Date of Substantial Completion.

END OF SECTION 104400