

## SECTION 096500 - RESILIENT FLOORING

### PART 1 GENERAL

#### 1.1 SECTION INCLUDES

- A. Resilient tile flooring.
- B. Resilient base.
- C. Resilient stair accessories.
- D. Installation accessories.

#### 1.2 RELATED REQUIREMENTS

- A. Section 033000 - Cast-in-Place Concrete: Restrictions on curing compounds for concrete slabs and floors to receive adhesive-applied resilient flooring.
- B. Section 260526 - Grounding and Bonding for Electrical Systems: Grounding and bonding of static control flooring to building grounding system.

#### 1.3 REFERENCE STANDARDS

- A. ASTM F1066 - Standard Specification for Vinyl Composition Floor Tile.
- B. ASTM F1700 - Standard Specification for Solid Vinyl Floor in Modular Format such as Tile(s) or Plank(s).
- C. ASTM F1861 - Standard Specification for Resilient Wall Base.
- D. ASTM F2169 - Standard Specification for Resilient Stair Treads.
- E. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings.

#### 1.4 SUBMITTALS

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Shop Drawings: Indicate seaming plans and floor patterns.
- D. Verification Samples: Submit two samples, minimum 2 by 2 inch<sup>2</sup> in size illustrating color and pattern for each resilient flooring product specified.
- E. Maintenance Data: Include maintenance procedures, recommended maintenance materials, and suggested schedule for cleaning, stripping, and re-waxing.

## 1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in installing specified flooring with minimum three years experience.
- B. Wall base, stair treads, reducer strips, and all other accessories to be from one manufacturer.

## 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store all materials off of the floor in an acclimatized, weather-tight space.
- B. Maintain temperature in storage area between 55 degrees F and 90 degrees F.
- C. Protect roll materials from damage by storing on end.

## 1.7 FIELD CONDITIONS

- A. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F.

## PART 2 PRODUCTS

### 2.1 TILE FLOORING

- A. Vinyl Composition Tile - Type VCT-1: Homogeneous, with color extending throughout thickness.
  - 1. Manufacturers:
    - a. Basis of Design: Tarkett Company; VCT II: [www.commercial.tarkett.com](http://www.commercial.tarkett.com).
    - b. Substitutions: See Section 016000 - Product Requirements.
  - 2. Minimum Requirements: Comply with ASTM F1066, of Class corresponding to type specified.
  - 3. Size: 12 by 12 inch.
  - 4. Thickness: 0.125 inch.
  - 5. Color: As indicated on drawings.

### 2.2 STAIR COVERING

- A. Stair Treads: Rubber; full width and depth of stair tread in one piece; tapered thickness.
  - 1. Manufacturers:
    - a. Basis of Design: Tarkett Flooring; \_\_\_\_\_: [www.tarkett.com/#sle](http://www.tarkett.com/#sle).
    - b. Substitutions: See Section 016000 - Product Requirements.
  - 2. Minimum Requirements: Comply with ASTM F2169, Type TS, rubber, vulcanized thermoset.
  - 3. Nosing: Square.
  - 4. Texture: Raised.
  - 5. Pattern: \_\_\_\_\_.
  - 6. Color: As indicated on drawings.

- B. Stair Stringers: Full height in one piece and in maximum available lengths, matching treads in material and color.
  - 1. Nominal Thickness: 0.080 inch.

## 2.3 RESILIENT BASE

- A. Resilient Base - Type WB-1: ASTM F1861, Type TS rubber, vulcanized thermoset; style as scheduled.
  - 1. Manufacturers:
    - a. Basis of Design: Johnsonite, a Tarkett Company; "Baseworks": [www.commercial.tarkett.com](http://www.commercial.tarkett.com).
    - b. Substitutions: See Section 016000 - Product Requirements.
  - 2. Height: 4 inches.
  - 3. Style: Cove base.
  - 4. Thickness: 0.125 inch.
  - 5. Finish: Matte.
  - 6. Length: Roll.
  - 7. Color: As indicated on drawings.

## 2.4 ACCESSORIES

- A. Subfloor Filler: White premix latex; type recommended by adhesive material manufacturer.
- B. Primers, Adhesives, and Seam Sealer: Waterproof; types recommended by flooring manufacturer.
- C. Moldings, Transition and Edge Strips:
  - 1. Manufacturer:
    - a. Basis of Design: Johnsonite, a Tarkett Company: [www.commercial.tarkett.com](http://www.commercial.tarkett.com).
    - b. Substitutions: See Section 016000 - Product Requirements.
  - 2. Color: Same as base
- D. Sealer and Wax: Types recommended by flooring manufacturer.

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive resilient base.
- C. Cementitious Subfloor Surfaces: Verify that substrates are ready for resilient flooring installation by testing for moisture and alkalinity (pH).
  - 1. Obtain instructions if test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.
- D. Verify that required floor-mounted utilities are in correct location.

### 3.2 PREPARATION

- A. Prepare floor substrates as recommended by flooring and adhesive manufacturers.
- B. Remove subfloor ridges and bumps. Fill minor low spots, cracks, joints, holes, and other defects with subfloor filler to achieve smooth, flat, hard surface.
- C. Prohibit traffic until filler is fully cured.
- D. Clean substrate.

### 3.3 INSTALLATION - GENERAL

- A. Starting installation constitutes acceptance of subfloor conditions.
- B. Install in accordance with manufacturer's written instructions.
- C. Adhesive-Applied Installation:
  - 1. Spread only enough adhesive to permit installation of materials before initial set.
  - 2. Place copper grounding strip in conductive adhesive and apply additional adhesive to top side of strip before installing static control flooring. Allow strip to extend beyond flooring in accordance with static control flooring manufacturer's instructions. Refer to Section 260526 for grounding and bonding to building grounding system.
  - 3. Fit joints and butt seams tightly.
  - 4. Set flooring in place, press with heavy roller to attain full adhesion.
- D. Where type of floor finish, pattern, or color are different on opposite sides of door, terminate flooring under centerline of door.
- E. Install edge strips at unprotected or exposed edges, where flooring terminates, and where indicated.
  - 1. Resilient Strips: Attach to substrate using adhesive.
- F. Scribe flooring to walls, columns, cabinets, floor outlets, and other appurtenances to produce tight joints.
- G. Install flooring in recessed floor access covers, maintaining floor pattern.

### 3.4 INSTALLATION - TILE FLOORING

- A. Mix tile from container to ensure shade variations are consistent when tile is placed, unless otherwise indicated in manufacturer's installation instructions.
- B. Lay flooring with joints and seams parallel to building lines to produce symmetrical pattern.
- C. Install plank tile with a random offset of at least 6 inches from adjacent rows.

### 3.5 INSTALLATION - RESILIENT BASE

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.
- B. Miter internal corners. At external corners, 'V' cut back of base strip to 2/3 of its thickness and fold. At exposed ends, use premolded units.

- C. Install base on solid backing. Bond tightly to wall and floor surfaces.
- D. Scribe and fit to door frames and other interruptions.

### 3.6 INSTALLATION - STAIR COVERINGS

- A. Install stair coverings in one piece for full width and depth of tread.
- B. Install stringers configured tightly to stair profile.
- C. Adhere over entire surface. Fit accurately and securely.

### 3.7 CLEANING

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean, seal, and wax in accordance with manufacturer's written instructions.

### 3.8 PROTECTION

- A. Prohibit traffic on resilient flooring for 48 hours after installation.

END OF SECTION 096500