

KEY NOTES:

- 1 COORDINATE INSTALLATION OF NEW 400-AMP ELECTRICAL SERVICE.
- 2 400-AMP DISCONNECT AND METER ON EXTERIOR OF BUILDING.
- 3 MAGNET LOCK WITH REMOTE SWITCH LOCATED IN OFFICE.
- 4 COORDINATE LOCATION OF WORK BENCHES, WORK STATIONS, AND DESKS WITH OWNER AND ARCHITECT. MAKE NECESSARY ADJUSTMENTS TO LOCATIONS OF DEVICES.
- 5 PROVIDE REQUIRED CONDUIT FOR ALL CAT 6 DATA WIRING FROM EACH DATA POINT BACK TO I.T. SWITCH. COORDINATE LOCATION OF I.T. SWITCH.


REVISIONS

#	DATE

A NEW
FACILITIES
SHOP
FOR:

OCONEE
COUNTY

WATKINSVILLE,
GEORGIA



AMERICAN
INSTITUTE
OF
ARCHITECTS
497 BROOMSEDGE COURT
BOLIVIA, NC
28422
(404) 285-8646

TITLE: FLOOR PLAN -
POWER &
SYSTEMS

JOB #: 2501
DATE: 09.11.26

SHEET #
E2

