



#	DATE	TITLE

PROJECT NUMBER:
00-000


1167 PACE ST. - PHASE I
1167 PACE ST, COVINGTON, GA

MECHANICAL PLAN

M101

THIS DRAWING AND THE FILE FROM WHICH IT HAS BEEN CREATED ARE AN INSTRUMENT OF SERVICE FOR THIS PROJECT. THESE DOCUMENTS ARE THE SOLE PROPERTY OF THE ARCHITECT, AND ANY USE OF THESE DOCUMENTS FOR PURPOSES OTHER THAN THOSE ASSOCIATED WITH THIS PROJECT IS STRICTLY PROHIBITED.

RELEASED FOR CONSTRUCTION



architecture - interiors - procure - (404)964-549 - www.creativelicense.studio

- KEY NOTES:**
1. 8"Ø EXHAUST WALL CAP.
 2. ROUTE 14"Ø DUCT TO RETURN PLENUM OF FAN COIL UNIT.
 3. ROUTE 6"Ø OUTSIDE AIR DUCT TO RETURN PLENUM OF FAN COIL UNIT. OUTSIDE AIR DUCT SHALL HAVE MANUAL AND MOTORIZED DAMPERS.
 4. FIELD COORDINATE LOCATION OF CONDENSING UNIT.
 5. ROUTE 12"Ø DUCT TO RETURN PLENUM OF FAN COIL UNIT.
 6. ROUTE 18"Ø DUCT TO RETURN PLENUM OF FAN COIL UNIT.
 7. EXPOSED DUCT SHALL BE PAINT GRIP, DOUBLE WALL SPIRAL. DUCT SHALL BE DENT FREE.
 8. 6"Ø OUTSIDE AIR WALL CAP.
 9. 8"Ø OUTSIDE AIR WALL CAP.
 10. 8"Ø OUTSIDE AIR DUCT SHALL HAVE MANUAL AND MOTORIZED DAMPERS.

